


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction 1/4 C 1/4 NW 1/4	Section number 12	Township number T 25 S R 16 E W	Range number
2. Distance and direction from nearest town or city: 3 1/2 S. 3 E. 1/4 S. East into field from Street address of well location if in city: Belpre, Ks.			3. Owner of well: Earl Westhoff R.R. or street: 2214 Polk City, state, zip code: Great Bend, Ks 67530		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 2 1/2 in. Completion date Well depth 138 ft. 6-3-77
Top soil			0	3	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Brown clay			3	31	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine sand Brown clay			31	42	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 138 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7
Brown yellow white clay			42	48	10. Screen: Manufacturer's name Doerr's Type Steel Dia. 1 1/2 in. MNC Slot/gauge 3/16 Length 60 Set between 78 ft. and 138 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 to 3/4
Sand and gravel			48	97	11. Static water level: _____ mo./day/yr. 24 ft. below land surface Date 4-4-77
White yellow brown clay			97	100	12. Pumping level below land surfaces: 34 ft. after 1 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400 g.p.m.
Sand and gravel			100	136	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4-4-77
Yellow white brown gray clay			136	143	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 800 Direction NE Type gas well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name Layne Bowler Model number 6-1084 HP 60 Volts _____ Length of drop pipe 70 ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks 67530 Signed Shirley Kilgore Date 6-29-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 25
R 16
E 12
Sec 12
1/4 C NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5