

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Meyer B #4 Edwards County

1. Location of well: County Edwards		Fraction 1320 N, 1320 W		Section number 16		Township number T 25 S R 16 E/W		Range number	
2. Distance and direction from nearest town or city: Belpre Ks 5 SOUTH 1/2 EAST 3/4 NORTH				3. Owner of well: D.R. LAUCK Delq					
Street address of well location if in city:				R.R. or street:					
City, state, zip code: Great Bend Kans.				6. Bore hole dia. 9 in. Completion date 6-24-78					
4. Locate with "X" in section below: Sketch map:				Well depth 73 ft.					
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other					
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 287.3 lbs./ft. Dia. 5 in. to 73 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200					
				10. Screen: Manufacturer's name Shop made					
				Type Saw Dia. 5 Slot/gauze 1/8 Length 20 Set between 53 ft. and 73 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8					
				11. Static water level: <input type="checkbox"/> mo./day/yr. 18 ft. below land surface Date 6-24-78					
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.					
				13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____					
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade					
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.					
				16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
				(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Meyer Water Well 143 Business name License No. 6-24-78 Address 6th Bond Ks Signature Raymond Rowland (Date) 6-24-78 Authorized representative					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley									

T 25
 R 16
 E 16
 Sec 16
 SE
 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5