

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>County</u> Edwards		Fraction C 1/4 SE 1/4 NE 1/4		Section number 18		Township number T 25 S		Range number R 16 W	
2. Distance and direction from nearest town or city: 1 1/2 miles south				3. Owner of well: D. R. Louck					
Street address of well location if in city: 1/2 South Belfrie				R.R. or street: Wichita					
City, state, zip code: Wichita, Miss									
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 8 in. Completion date 11-7-77					
				Well depth 60 ft.					
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other					
				9. Casing: Material Plastic Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 72 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 287.3 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 200					
5. Type and color of material				From		To		10. Screen: Manufacturer's name Self made	
Clay				0		10		Type PVC Dia. 5	
sandy clay				10		30		Slot 1/8 Length 70	
sandy				30		40		Set between 20 ft. and 20 ft.	
Gravel				40		60		Gravel pack yes Size range of material 1/8 - 1/4	
								11. Static water level: 20 ft. below land surface Date 11-7-77	
								12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 100 g.p.m.	
								13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____	
								14. Well head completion: <input type="checkbox"/> Pitless adapter ____ Inches above grade	
								15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
								16. Nearest source of possible contamination: ft. ____ Direction ____ Type well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Meyer Water Well Business name 143 license no. ____ Address W Bond, Mo Signed C Meyer 11-7-77 Authorized representative Date	
18. Elevation:		19. Remarks:							
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley									

T 25 S R 16 W E 18 CSENE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5