

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: EDWARDS	Fraction: C 1/4 NW 1/4 SE 1/4	Section number: 32	Township number: T 25 S	Range number: R 16 E/W															
2. Distance and direction from nearest town or city: Bellevue 7 SOUTH 1320 WEST			3. Owner of well: Huskey Dalg																	
Street address of well location if in city:			R.R. or street:																	
4. Locate with "X" in section below:			Sketch map:																	
			6. Bore hole dia. 9 in. Completion date: 6-12-78																	
			Well depth 70 ft.																	
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug																	
			<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Sandy Clay</td> <td>0</td> <td>30</td> </tr> <tr> <td>Clay</td> <td>30</td> <td>40</td> </tr> <tr> <td>Fine Sand</td> <td>40</td> <td>50</td> </tr> <tr> <td>Gravel</td> <td>50</td> <td>70</td> </tr> </tbody> </table>				From	To	Sandy Clay	0	30	Clay	30	40	Fine Sand	40	50	Gravel	50	70	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
				From	To															
Sandy Clay	0	30																		
Clay	30	40																		
Fine Sand	40	50																		
Gravel	50	70																		
			<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock																	
			<input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other																	
			9. Casing: Material PVC Height: Above or below																	
			Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in.																	
			RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 287.3 lbs./ft.																	
			Dia. 5 in. to 70 ft. depth Wall Thickness: inches or																	
			Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200																	
			10. Screen: Manufacturer's name Shop made																	
			Type Saw Dia. 5																	
			Slot/gauze 1/8 Length 20																	
			Set between 50 ft. and 70 ft.																	
			ft. and <input type="checkbox"/> ft.																	
			Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/8																	
			11. Static water level: <input type="checkbox"/> mo./day/yr.																	
			22 ft. below land surface Date 6-12-78																	
			12. Pumping level below land surfaces:																	
			<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.																	
			<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.																	
			Estimated maximum yield <input type="checkbox"/> g.p.m.																	
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr.																	
			<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>																	
			14. Well head completion:																	
			<input type="checkbox"/> Pitless adapter 12 Inches above grade																	
			15. Well grouted? <input checked="" type="checkbox"/> Yes																	
			With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete																	
			Depth: From 0 ft. to 20 ft.																	
			16. Nearest source of possible contamination:																	
			ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/>																	
			Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No																	
			17. Pump: <input checked="" type="checkbox"/> Not installed																	
			Manufacturer's name <input type="checkbox"/>																	
			Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/>																	
			Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.																	
			Type:																	
			<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine																	
			<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating																	
			<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																	
			18. Elevation:																	
19. Remarks:			20. Water well contractor's certification:																	
			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.																	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			More Water Well 143 Business name License No.																	
			Address 600 Bend St Signed Raymond Randall Date 6-17-78 Authorized representative																	

T
R
E
S
E
C
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5