

## WATER WELL RECORD KSA 820-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction	Fraction 1/4 1/4CNW 1/4		Section	number	Township number	Range number	
1. Location of well:	Edwards	1/4			1/4 36		T 25 S	R 16	E (W)
2. Distance and direction from nearest town or city:  10 mi. SE of Belpre, KS  R.R. or					ner of well: Ray Cudney street: Route 1				
Street address of well location if in city:  City, s							Frousdale, KS 67145		
4. Locate with "X" in N		Sketch mop:					6. Bore hole dia, $\frac{24}{100}$ in. Well depth $\frac{100}{100}$ ft.	Completion date 4	-/-/6
W	I I NE						7 Cable tool Rotary Hollow rad Jetted		rse rotary
W 1	-   						8. Use: Domestic Pu <u>X</u> Irrigation Ai Lawn Oi	r conditioning St	
sw	SE						9. Casing: MaterialSteel	Height Above r	elow
<u> </u>							Threaded Welded <u>X</u> RMP PVC		in. lbs./ft.
5. Type and color of material					From	То	Dia. 16 in. to 60 ft. depth Wall Thickness: inches or Dia in. to ft. depth gage No. 7 gae		
	· · · · · · · · · · · · · · · · · · ·				<u> </u>		10. Screen: Manufacturer's n	Doerr Doerr	
top soil					0	3	Type Double-slot Dia. 16**  (Slot) gauze 1/8** Length 40		
sand					3	8	Set between		
sand & gravel					8	12			
gray clay					12	18	11. Static water level: mo./day/yr.  7		
sand & gravel					18	24	12. Pumping level below land		g.p.m.
brown & white clay & limestone					24	33	ft. after hrs. pumping g.p.m.  Estimated maximum yield g.p.m.		
sand & grav	vel & thin clay s	streaks at	46,49,7	4	33	100	13. Water sample submitted:	то	/day/yr.
& 80	<del>,</del>	·					14. Well head completion:	2 Inches above	grade
					<del>                                     </del>		15. Well grouted? <u>Yes</u> With: <u>X</u> Neat cement  Depth: From	Bentonite	Concrete _
							NONE KNOWN 16. Nearest source of possible ft Direction	e contamination:	
							Well disinfected upon comple	tion?Yes_	X No
	· · · · · · · · · · · · · · · · · · ·	,					17. Pump:  Manufacturer's name FMC  Model number 12LB-3	Corp./Peer	
	,						Length of drop pipe 60  Type:	_ ft. capacity 90	) <sub>g.p.m.</sub>
							Submersible	<u>X</u> Turbine Recipro	
······································	(Use a seco	and sheet if needed)					Centrifugal	Other	× *
18. Elevation:	19. Remarks:						20. Water well contractor's of This well was drilled under m	y jurisdiction and this	report
Topography:							is true to the best of my know Clarke Well & E	. Inc.	185 <sup>-</sup>
Hill Slope							Business name Address Great Bend	, KS 67530	ense No.
Upland							Signed Authorized rep	resentative Date	ā <b>-18-</b> ∤6