

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction SW 1/4 NE 1/4 SE 1/4	Section number 20	Township number T 25 S R	Range number 16 1/W
2. Distance and direction from nearest town or city: 5 1/2 South of Belpre Street address of well location if in city:				3. Owner of well: D. R. Lauck Drilling Co. R.R. or street: 1201 Washington City, state, zip code: Great Bend, Ks.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 3/4 in. Completion date _____ Well depth 80 ft. 12-22-76		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sandy Top Soil				0	4	9. Casing: Material pvc Height: Above or below Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC 160 Weight 16 lbs./ft. Dia. 4 in. to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 4
Brown Clay Clay				4	13	10. Screen: Manufacturer's name _____ Type pvc Dia. 4 Slot/gauge 1/16 Length 20 Set between 45 ft. and 65 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/2 3/4 3/8
Sand Gravel				13	18	11. Static water level: _____ mo./day/yr. 13 ft. below land surface Date 12-22-76
Brown Clay				18	38	12. Pumping level below land surfaces: 13 ft. after 1 hrs. pumping 100 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Sand & Gravel				38	65	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Brown Clay				65	80	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade <input checked="" type="checkbox"/> Well grouted? NO With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From _____ ft. to _____ ft.
						16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes _____ No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks: <i>(Use 2 second sheet if needed)</i> well was pulled & plugged with sand + gravel				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis License No. 134 Business name Great Bend, Ks. Address Great Bend, Ks. Signed Fredia Weston Date 12/27/76 Authorized representative				

T
R
Sec
1/4
1/4
1/4
1/4
25-160-20 SUMNER SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5