

OFFICE USE ONLY

T

25

R

18

EW

SEC

SE 1/4

NE 1/4

NE 1/4

1 LOCATION OF WATER WELL		Fraction			Section Number		Township Number		Range Number		
County: <u>Edwards</u>		SE 1/4 NE 1/4 NE 1/4			8		T 25 S		R 18 EW		
Distance and direction from nearest town or city? <u>2 1/2 S, 3 W, 1/8 S of Lewis</u>					Street address of well if located within city?						
2 WATER WELL OWNER: <u>Bill McLean</u>											
RR#, St. Address, Box # :							Board of Agriculture, Division of Water Resources				
City, State, ZIP Code : <u>Lewis, Ks. 67552</u>							Application Number:				
3 DEPTH OF COMPLETED WELL: <u>80</u> ft. Bore Hole Diameter: <u>11</u> in. to <u>80</u> ft., and <u> </u> in. to <u> </u> ft.											
Well Water to be used as:											
<input type="radio"/> Domestic			5 Public water supply			8 Air conditioning			11 Injection well		
3 Feedlot			6 Oil field water supply			9 Dewatering			12 Other (Specify below)		
2 Irrigation			4 Industrial			7 Lawn and garden only			10 Observation well		
Well's static water level: <u>29</u> ft. below land surface measured on <u>10</u> month <u>1</u> day <u>80</u> year											
Pump Test Data: Well water was <u> </u> ft. after <u> </u> hours pumping <u> </u> gpm											
Est. Yield: <u>NA</u> gpm; Well water was <u> </u> ft. after <u> </u> hours pumping <u> </u> gpm											
4 TYPE OF BLANK CASING USED:											
1 Steel			3 RMP (SR)			5 Wrought iron			8 Concrete tile		
<input type="radio"/> PVC			4 ABS			6 Asbestos-Cement			9 Other (specify below)		
						7 Fiberglass			Casing Joints: <input checked="" type="checkbox"/> Glued <input type="checkbox"/> Clamped		
									Welded		
									Threaded		
Blank casing dia: <u>5</u> in. to <u>55</u> ft., Dia: <u> </u> in. to <u> </u> ft., Dia: <u> </u> in. to <u> </u> ft.											
Casing height above land surface: <u>12</u> in., weight <u> </u> lbs./ft. Wall thickness or gauge No: <u>.258</u>											
TYPE OF SCREEN OR PERFORATION MATERIAL:											
1 Steel			3 Stainless steel			5 Fiberglass			<input type="radio"/> PVC		
2 Brass			4 Galvanized steel			6 Concrete tile			8 RMP (SR)		
									9 ABS		
									10 Asbestos-cement		
									11 Other (specify)		
									12 None used (open hole)		
Screen or Perforation Openings Are:											
1 Continuous slot			3 Mill slot			5 Gauzed wrapped			<input checked="" type="radio"/> Saw cut		
2 Louvered shutter			4 Key punched			6 Wire wrapped			9 Drilled holes		
						7 Torch cut			11 None (open hole)		
									10 Other (specify)		
Screen-Perforation Dia: <u>5</u> in. to <u>75</u> ft., Dia: <u> </u> in. to <u> </u> ft., Dia: <u> </u> in. to <u> </u> ft.											
Screen-Perforated Intervals: From <u>55</u> ft. to <u>75</u> ft., From <u> </u> ft. to <u> </u> ft., From <u> </u> ft. to <u> </u> ft.											
Gravel Pack Intervals: From <u>10</u> ft. to <u>80</u> ft., From <u> </u> ft. to <u> </u> ft., From <u> </u> ft. to <u> </u> ft.											
5 GROUT MATERIAL:											
<input type="radio"/> Neat cement			2 Cement grout			3 Bentonite			4 Other		
Grouted Intervals: From <u>0</u> ft. to <u>10</u> ft., From <u> </u> ft. to <u> </u> ft., From <u> </u> ft. to <u> </u> ft.											
What is the nearest source of possible contamination:											
<input type="radio"/> Septic tank			4 Cess pool			7 Sewage lagoon			10 Fuel storage		
2 Sewer lines			5 Seepage pit			8 Feed yard			11 Fertilizer storage		
3 Lateral lines			6 Pit privy			9 Livestock pens			12 Insecticide storage		
									13 Watertight sewer lines		
									14 Abandoned water well		
									15 Oil well/Gas well		
									16 Other (specify below)		
Direction from well: <u>N</u> How many feet: <u>150</u> ? Water Well Disinfected? Yes <u>HHH</u> No											
Was a chemical/bacteriological sample submitted to Department? Yes <input checked="" type="checkbox"/> No: If yes, date sample was submitted: <u>10</u> month <u>1</u> day <u>80</u> year: Pump Installed? Yes <input checked="" type="checkbox"/> No											
If Yes: Pump Manufacturer's name: <u>Red Jacket</u> Model No.: <u>800</u> HP: <u>1</u> Volts: <u>230</u>											
Depth of Pump Intake: <u>42</u> ft. Pumps Capacity rated at: <u>18</u> gal./min.											
Type of pump: <input type="radio"/> Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other											
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on <u>10</u> month <u>27</u> day <u>80</u> year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>134</u>											
This Water Well Record was completed on <u>11</u> month <u>4</u> day <u>80</u> year under the business name of <u>Rosencrantz-Bemis</u> by (signature) <u>Lora Dodson</u>											
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG				
		0	2	Top soil							
		2	6	Brown sandy clay							
		6	7	Gray clay							
		7	24	Fine sand and gravel w/ brown and gray clay mixed							
		24	65	Sand and gravel							
		65	80	Sand and gravel w/ clay							
ELEVATION:											
Depth(s) Groundwater Encountered: 1. <u>29</u> ft. 2. <u> </u> ft. 3. <u> </u> ft. 4. <u> </u> ft. (Use a second sheet if needed)											
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.											