

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

✓ #2

1. Location of well:		County Edwards	Fraction 1/4 1/4 1/4	Section number 26	Township number T 25 S R 18 E/W	Range number
2. Distance and direction from nearest town or city: 6.5 - 3/4 W - 1/4 N of Harris				3. Owner of well: Rex Neff R.R. or street: City, state, zip code: Kinsley, KS.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 16 in. Completion date 4-8-76 Well depth 167 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy Top Soil		0	2	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 167 ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. _____		
Brown & Gray Clay		2	36	10. Screen: Manufacturer's name Dorris Type steel Dia. 16 slot gauge 3/16 Length 88 Set between 19 ft. and 167 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8		
Fine to Coarse Sand to Fine Gravel		36	53	11. Static water level: _____ mo./day/yr. 31 ft. below land surface Date 2-75		
Gray Clay		53	65	12. Pumping level below land surfaces: 26 ft. after 12 hrs. pumping 1400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1600 g.p.m.		
Med. to Coarse Sand to coarse gravel-drilled med.		65	88	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
Gray Clay		88	119	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Med. to Coarse Sand to med. Gravel		119	141	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Gray Clay		141	143	16. Nearest source of possible contamination: ft. 140 Direction 2 Type canal Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Med. to Coarse Sand to Med. Gravel		143	149	17. Pump: _____ Not installed Manufacturer's name WLR Model number 5CH-12 HP 80 Volts _____ Length of drop pipe 85 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Gray Clay		149	153			
Med. to Coarse Sand to Med. Gravel		153	167			
Gray Clay with Sand lenses		167	187			
Blue Shale		187	190			
(Use a second sheet if needed)						
18. Elevation: 2175		19. Remarks: 31317 25 18 26 NCX			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Resencrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, KS. Signed Fredia Reddon Date 9/25/76 Authorized representative	

25
18
26
NCX
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5