

27

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 27	Township number T 25 S R	Range number 18 W
2. Distance and direction from nearest town or city: 6.5 mi 1/4 E of Lewis Street address of well location if in city:			3. Owner of well: Pat Platts R.R. or street: City, state, zip code: Lewis, Mo 67552		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 7 7/8 in. Completion date _____ Well depth 60 ft. 11-2-76	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top Soil		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown Clay		2	9	9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia. 4 in. to 60 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 1/4	
Brown Clay with Some Sand & Gravel		9	14	10. Screen: Manufacturer's name R/B Type pvc Dia. 4 Slot/gauze 1/16 Length 20 Set between 40 ft. and 60 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material _____	
Sand & Gravel (med.)		14	28	11. Static water level: _____ mo./day/yr. 18 1/2 ft. below land surface Date 11-2-76	
Brown Clay		28	30	12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Clean Coarse Sand & Gravel		30	60	<input checked="" type="checkbox"/> Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 11-2-76	
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 3/4 Direction North Type Corral Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: 2181 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks. Signed Fredia Dodson Date 11-6-76 Authorized representative	

T 25 S R 18 W
 Sec 27 SE SE SE SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5