

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

V #4

1. Location of well:		County <b>Edwards</b>	Fraction <b>CNE</b> 1/4 1/4 1/4	Section number <b>27</b>	Township number <b>T 25</b>	Range number <b>S R 18</b>	E/W
2. Distance and direction from nearest town or city: <b>5.5-1W-14S-16W of Lawrence, Ks</b> Street address of well location if in city:				3. Owner of well: <b>Rex Neff</b> R.R. or street: City, state, zip code: <b>Kinsley, Ks</b>			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 			6. Bore hole dia. <b>2 1/2</b> in. Completion date <b>4-9-76</b> Well depth <b>173</b> ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top Soil			0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown silty Sand			2	11	9. Casing: Material <b>Steel</b> Height: <b>Above or below</b> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>18</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <b>16</b> in. to <b>173</b> ft. depth Wall Thickness, inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>7</b>		
Fine to Coarse Sand with silt lenses			11	43	10. Screen: Manufacturer's name <b>Doerrs</b> Type <b>Steel</b> Dia. <b>16</b> Slot gage <b>3/16</b> Length <b>80</b> Set between <b>93</b> ft. and <b>173</b> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/2 3/4 3/8</b>		
Med. to coarse Sand to med. Gravel			43	55	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>27</b> ft. below land surface Date <b>4-75</b>		
Brown clay			55	61	12. Pumping level below land surfaces: <b>32</b> ft. after <b>12</b> hrs. pumping <b>1400</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>1600</b> g.p.m.		
Med. to coarse sand & Gravel			61	103	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
Gray Clay - hard			103	124	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Med. to coarse sand to med. gravel			124	140	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
Gray Clay			140	147	16. Nearest source of possible contamination: ft. <b>3/4 m</b> Direction <b>W</b> Type <b>concrete</b>		
Med. to coarse sand to med. gravel			147	157	Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Gray Clay			157	161	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>WLR</b> Model number <b>S-CH-12</b> HP <b>80</b> Volts <input type="checkbox"/> Length of drop pipe <b>80</b> ft. capacity <b>800</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Med. to coarse sand to med. gravel			161	175			
Brown Clay			175	176			
Blue shale			176	180			
(Use a second sheet if needed)							
18. Elevation: <b>2185</b> Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <b>31317</b> <b>25 18 27 NAX</b>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rosenkrantz Bemis 134</b> Business name License No. Address <b>Great Bend, Ks.</b> Signed <b>Fredia Radson</b> Date <b>9/23/76</b> Authorized representative		

25 18 W 27 CNE  
 1/4 1/4 1/4  
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5