USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

## WATER WELL RECORD KSA 82a-1201-1215



Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Fraction		Secti	on number	Township number	Range number	
	Edwards	C 1/4 SW 1/4 (ne)	) <sub>4</sub>	35	т 25 s	R 18	E (d)
2. Distance and direction from nearest town or city:				ell:	Marlin Butler		
6 South -lwest of Lewis , Ks.  Street address of well location if in city:  City, sto					Lewis, Ks.		
4. Locate with ルメード	n section below:	6. Bore hole dia. 29 in	. Completion date				
4. Locate with 以不可 in section below: Sketch map: N					Well depth 164 ft.		4-76
NW NE					7Cable tool X_ Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary		
SW - SE					Lawn Oil field water Other		
					9. Casing: Material stee Height: Above or below Threoded Welded _X   Surface in.		
<u> </u>					RMPPVCWeight_7_ga_lbs./ft.		
ı→ 1 Mile → ı					Dia. 16 in. to 164. depth Wall Thickness: inches or Dia in. to ft. depth !gage No		
5. Type and color of material				То	10. Screen: Manufacturer's name		
Top soil				3	Doerrs		
			C	1.	Type		
Brown clay			3	4	Set betweenft. andft.		
Brown clay and fine sand			4	16	ft. andft.  Gravel pack?  Size range of material \$\frac{1}{2} - \frac{3}{8} - \frac{3}{8} - \frac{4}{3}		
Brown and white clay				18	11. Static water level: mo./day/yr. 20_ft. below land surface Date 9=23-76		
Brown & white clay some sand and gravel				20	12. Bumping level below land surfaces:		
					ft. after hrs. pumping g.p.m.   g.p.ping g.p.m.		
Good clean send and gravel				52	Estimated maximum yield 1400 g.p.m.		
Fine sahd & brown clay				2 54	13. Water sample submitted:mo./day/yr.   X		
Fine sand and gravel				+ 74	14. Well heod completion:		
Light brown clay				10	Pitless adapter  15. Well grouted?	Inches above gr	ade
White clav				109	With: Neat cement Bentonite X Concrete		
				120	16. Negrest source of possible	contamination:	- 10°
					ft. 1800 Direction nw Type cemetary Well disinfected upon completion? Yes No		
Fine red and brown clay				0 12	17. Pump:	Not installed	
*KIKKXKX	Karlaxx Sand 8	and gravel	126	130	Manufacturer's name	Jacuzzi _ HP _ 60 _ Volts	— P
Hard white clay			130	1 50	Length of drop pipe 80	70113	.p.m. <b>3</b> m
Fine sand and gravel			150	163	Submersible	X Turbine	بدار ا
Brown and gray clay a second sheet if needed)			16	174	Jet Centrifugal	Reciproco	ating S
18. Elevation: 19. Remarks:					20. Water well contractor's o		
					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography:					Rosencrantz	-Bemis 13	,
Hill Slope					Address Great Bend. Ks.		
Valley					Signed Justia La Authorized repo	Date Date	1/19/70
Forward the white, blue	e and pink copies to the Department of	of Health and Environment				Form WWC	5 M