

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 8	Township number T 25 S R 19 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 mi S of Kinsley West Street address of well location if in city:			3. Owner of well: Myron Burr R.R. or street: NA City, state, zip code: Kinsley, Ks. 67547			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date 8-11-77 Well depth 36 ft.		
		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 24 in. to 36 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7		
5. Type and color of material				From	To	10. Screen: Manufacturer's name Goerno
Top soil				0	2	Type steel Dia. 24
Clay				2	3	Slot 3/16 Length 12
Sand & gravel				3	43	Set between 24 ft. and 36 ft.
Brown clay				43	55	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 1 1/2
						11. Static water level: 6 ft. below land surface Date 12-30-76 mo./day/yr.
						12. Pumping level below land surfaces: 20 ft. after 2 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 600 g.p.m.
						13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 12-30-76 mo./day/yr.
						14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 2600 Direction East Type septic Well disinfected upon completion? HH Yes <input type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name W.T.R. Model number 3-1000 HP 30 Volts 460 Length of drop pipe 30 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosecrantz Lemis 134 Business name License No. Address Shea Bend to 67547 Signed Sandy Hilborn Date 7-8-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5