

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction C 1/4 NW 1/4 NE 1/4	Section number 9	Township number T 25 S	Range number R 19 E/W
2. Distance and direction from nearest town or city: 1 mi S. 1/4 W - 30. into field from Street address of well location if in city: Kinsley, Ks.			3. Owner of well: Myron Burr R.R. or street: NA City, state, zip code: Kinsley, Ks. 67547		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 29 in. Completion date Well depth 52 ft. 8-11-77
Top soil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Brown clay			2	3	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sand & gravel			3	26	9. Casing: Material steel Height: Above on top Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 52 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7
Brown clay			26	27	10. Screen: Manufacturer's name Doerr
Sand & gravel			27	47	Type steel Dia. 1 1/2 Slot/gauze 3/16 Length 8 Set between 44 ft. and 52 ft. _____ ft. and _____ ft.
Gray clay			47	55	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 1
Shale			55	58	11. Static water level: _____ mo./day/yr. 9 ft. below land surface Date 11-22-76
					12. Pumping level below land surfaces: 22 ft. after 1 hrs. pumping 200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 650 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 11-22-76
					14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: Barnyard ft. 2000 Direction NE Type septic Well disinfected upon completion? NA Yes <input type="checkbox"/> No <input type="checkbox"/>
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: 2174' Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Branco-Burris 134 Business name _____ License No. _____ Address Heat Bend Ks. 67530 Signed Samuel K. Burr Date 7-8-77 Authorized representative		

T 25 S
 R 19 E
 Sec 9
 CAWNE
 1/4 1/4 1/4