


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County SERGEWICK	Township name EAGLE	Fraction NE SW SW	Section number 11	Town number 25	Range number 2 W
Distance and direction from nearest town or city: 1 N. of BENTLEY, KS.				3 Owner of well: LARRY SCHROEDER		
Street address of well location if in city:				Address: BENTLEY, KS.		
Locate with "X" in section below: N  W S E 1 Mile		Sketch map:		4 Well depth: 50 ft. Date of completion 3-30-77 Well diameter 8 in.		
2 Type and color of material		From To		5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
				6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well		
				7 Casing: Material Steel Height 0 above/below Threaded ☐ Welded ☒ Surface 12 in. Diam. 5 in. to 50 ft. depth Drive shoe? ☐ Yes ☐ No 5 in. to 50 ft. depth		
				8 Screen: Manufacturer Y&L Type 200 Dia. 5" Slot/gauze .065 Length 10' Set between 40 ft. and 50 ft. Fittings: Gravel pack ☒ Yes ☐ No Size range of material		
				9 Static water level: 15 ft. below land surface Date 3-30-77		
(use a second sheet if needed)				10 Pumping level below land surfaces: 15 ft. after 2 hrs. pumping 10 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.		
				11 Water sample submitted: ☐ Yes ☒ No Date		
				12 Well head completion: ☐ Pitless adapter ☒ 12" inches above grade		
				13 Well grouted? ☐ Yes ☒ No ☐ Neat cement ☐ Bentonite Depth: From ft. to ft.		
				14 Nearest source of possible contamination: ft. 60 Direction N Type Septic Well disinfected upon completion? ☐ Yes ☒ No		
16 Remarks: elevation Topography: ☐ Hill ☐ Slope ☐ Upland ☒ Valley				15 Pump: ☒ Not installed Manufacturer's name Remington Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 21st Electric 129 Business name License No. Address 512 W. 21st Signed J. Davis Date 4-18-77 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5