

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

OFFERLE SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction SW/4 SW 1/4 NE 1/4	Section number 36	Township number T 25 S R 21	Range number 21 E (W)
2. Distance and direction from nearest town or city: 1/2 W, 3S, 10 of Offerle			3. Name of well: William E. Herrmann			
Street address of well location if in city:			R.R. or street: City, state, zip code: Offerle, Kansas 67563			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia 9 7/8 in. Completion date _____ Well depth 60 ft. 5-16-79		
		<p>7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material PVC Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. .265</p>		10. Screen: Manufacturer's name _____ Pumpco Type PVC Dia. 5" Slot/gauze fine Length 45' Set between 15 ft. and 60 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material #1 fine		
				11. Static water level: _____ mo./day/yr. 8 ft. below land surface Date 5/14/79		
5. Type and color of material		From	To	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Top Soil		0	5	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay		5	15	14. Well head completion: _____ Pitless adapter 18 inches above grade		
Fine Sand		15	25	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
Clay with sand (sticky)		25	60	16. Nearest source of possible contamination: ft. 20 Direction NW Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
				17. Pump: _____ Not installed Manufacturer's name Customers Tower Model number _____ HP _____ Volts _____ Length of drop pipe 21 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed <i>[Signature]</i> Date 6-15-79 Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		TOPU		2264		

T 25
 R 21
 E (W)
 S 36
 Sec SW
 1/4 SW
 1/4 SW
 1/4 SW