

1 LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: <u>Ford</u>	<u>NW 1/4 NW 1/4 SW 1/4</u>	<u>13</u>	<u>T 25 S</u>	<u>R 22 EW</u>

Distance and direction from nearest town or city? 3 miles East of Spearville, Kansas and 3/4 mile North

Street address of well if located within city?

2 WATER WELL OWNER: Chuck Conrardy

RR#, St. Address, Box # : \_\_\_\_\_

City, State, ZIP Code : Spearville, Kansas 67876

Board of Agriculture, Division of Water Resources  
Application Number: \_\_\_\_\_

3 DEPTH OF COMPLETED WELL 75 ft. Bore Hole Diameter 8 in. to \_\_\_\_\_ ft., and \_\_\_\_\_ in. to \_\_\_\_\_ ft.

Well Water to be used as:

5 Public water supply	8 Air conditioning	11 Injection well
1 Domestic	3 Feedlot	6 Oil field water supply
2 Irrigation	4 Industrial	7 Lawn and garden only
9 Dewatering	10 Observation well	12 Other (Specify below)

Well's static water level 41 ft. below land surface measured on August month 10 day 1980 year

Pump Test Data

Est. Yield 21 gpm: Well water was 75 ft. after 2 hours pumping. 21 gpm

4 TYPE OF BLANK CASING USED:

1 Steel	5 Wrought iron	8 Concrete tile	Casing Joints: Glued <u>XX</u> Clamped _____
2 PVC	6 Asbestos-Cement	9 Other (specify below)	Welded _____
4 ABS	7 Fiberglass		Threaded _____

Blank casing dia 5 in. to 75 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.

Casing height above land surface 12 in., weight \_\_\_\_\_ lbs./ft. Wall thickness or gauge No. 205 Jet stream

TYPE OF SCREEN OR PERFORATION MATERIAL:

1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-cement
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS	11 Other (specify) _____
				12 None used (open hole)

Screen or Perforation Openings Are:

1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes	
		7 Torch cut	10 Other (specify) _____	

Screen-Perforation Dia 1/8 in. to 20 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.

Screen-Perforated Intervals: From 45 ft. to 65 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel Pack Intervals: From 20 ft. to 75 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

5 GROUT MATERIAL

1 Neat cement	2 Cement grout	3 Bentonite	4 Other _____
---------------	----------------	-------------	---------------

Grouted Intervals: From 7 ft. to 20 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

What is the nearest source of possible contamination:

1 Septic tank	4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well
2 Sewer lines	5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well
3 Lateral lines	6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)
			13 Watertight sewer lines	

Direction from well \_\_\_\_\_ How many feet \_\_\_\_\_ ? Water Well Disinfected? Yes XXXX No \_\_\_\_\_

Was a chemical/bacteriological sample submitted to Department? Yes \_\_\_\_\_ No XXXX If yes, date sample was submitted \_\_\_\_\_ month \_\_\_\_\_ day \_\_\_\_\_ year: Pump Installed? Yes XXXX No \_\_\_\_\_

If Yes: Pump Manufacturer's name Goulds Model No. 10EJ07412 HP 3/4 Volts 230

Depth of Pump Intake 59 ft. Pumps Capacity rated at 10 gal./min.

Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Oct. month 1980 day \_\_\_\_\_ year \_\_\_\_\_

and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179

This Water Well Record was completed on Nov. month 1 day 1980 year under the business name of Joe's Well Service Cimarron, Kansas by (signature) Joe's Well Service

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM		TO		LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	15	15	30				
	0	15	15	30	Top soil & clay			
	15	30	30	45	Clay & fine sand(9ft.)			
	30	45	45	60	Fine to medium sand & rock layers			
	45	60	60	75	Medium to coarse (some) sand & rock layers also clay & blue shale			
	60	75	75		Rock layers & blue shale			

ELEVATION: \_\_\_\_\_

Depth(s) Groundwater Encountered 1. \_\_\_\_\_ ft. 2. \_\_\_\_\_ ft. 3. \_\_\_\_\_ ft. 4. \_\_\_\_\_ ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY

T

R

SEC.

NW 1/4

SW 1/4