

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABD
300' north of center

20061 CITY SW

1. Location of well: County **Ford** Fraction **NE 1/4** Section number **32** Township number **T 25 S R 26** Range number **E/W**

2. Distance and direction from nearest town or city: **2-3/4 north-1/2 west-3/4 north-1/4 west**
Street address of well location if in city: **Howell, Kansas**

3. Owner of well: **Schraeder Farms**
R.R. or street: **2206 5th Ave.**
City, state, zip code: **Dodge City, Kansas**

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. **3 3/8** in. Completion date **2-10-78**
Well depth **232** ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material **metal** Height: Above or below
Threaded Welded Surface **10** in.
RMP PVC Weight **31.66** lbs./ft.
Dia. **16** in. to **232** ft. depth Wall Thickness: inches or
Dia. in. to ft. depth gauge No. **188**

5. Type and color of material	From	To
Surface hard bit		10
Brown clay	3	30
Coleche clay and rock	50	75
Fine sand with 10% clay mixed	75	92
Med. sand and gravel	92	97
Cemented gravel	97	99
Fine to 1/2 med. sand	99	118
Fine to 1/2 med. sand with some clay mixed	118	142
Clay	142	146
Med. sand with 5% clay mixed	146	152
Brown clay	152	173
Med. sand with 5% clay mixed	173	191
Good fine to med. sand with 5% clay mixed	191	230
Yellow clay	230	234
Blue shale	234	240
BRock 230'		
90'		
140' salt thick		

10. Screen: Manufacturer's name **W.A. Brown**

Type **17% Free-flo** Dia. **16"**
Slot/gauze **1/8** Length **140**
Set between **92** ft. and **232** ft.
ft. and ft.
Gravel pack? **yes** Size range of material **3/8 CMA**

11. Static water level: mo./day/yr.
90 ft. below land surface Date **2-10-78**

12. Pumping level below land surfaces:
220 ft. after **4** hrs. pumping **700** g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield **700** g.p.m.

13. Water sample submitted: mo./day/yr.
Yes No Date

14. Well head completion:
 Pitless adapter Inches above grade

15. Well grouted? **yes**
With: Neat cement Bentonite Concrete
Depth: From **0** ft. to **10** ft.

16. Nearest source of possible contamination: **field**
ft. Direction Type
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name **Goulds**
Model number **10JMC** HP **60** Volts
Length of drop pipe **220** ft. capacity **550** g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: **1010**

19. Remarks: **1665**
250
2155

Topography:
 Hill
 Slope
 Upland
 Valley

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Ace-Hi International **190**
Business name License No.
Address **Dodge City, Kansas**
Signed **Carl G. Tuttle** Date **2-23-78**
Authorized representative

25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50