


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	NE _{1/4} NE _{1/4} NW _{1/4}	#26	T #25	S R #27 E _{1/4}
2. Distance and direction from nearest town or city: 1 mile north, 5 east and 2 north and $\frac{1}{2}$ mile east of Cimarron Street address of well location if in city: Ks.			3. Owner of well: Frank Redger (Redger Bros.) R.R. or street: North Star Route City, state, zip code: Cimarron, Kansas 67835		
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 8 in. Completion date 2-10-76 Well depth 230 ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil & brown clay	0	15	9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight _____ lbs./ft. Dia. 5 in. to 230 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250		
Brown clay & gyp rock	15	30	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot <input checked="" type="checkbox"/> 1/8" Length 20 ft. Set between 205 ft. and 225 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material $\frac{1}{4}$ "		
Fine sand & white rock	30	45	11. Static water level: 88 mo./day/yr. ft. below land surface Date 2-10-76		
White rock & fine sand	45	60	12. Pumping level below land surfaces: 88 ft. after 2 hrs. pumping 60 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.		
Fine to medium sand	60	75	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Medium sand	75	90	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade		
Medium sand & clay	90	105	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
Clay & fine sand	105	120	16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____		
Fine sand & clay layers	120	135	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Fine sand	135	150	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine to medium sand	150	165	18. Elevation: 19. Remarks: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley No contamination - just a stock well		
Medium sand	165	210	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name Box 174 Cimarron, Ks. License No. Address _____ Signed <u>Larry L. Clegg</u> Date 5-25-76 Authorized representative		
Medium to coarse sand	210	225			
Coarse sand, clay & blue shale	225	240			
(Use a second sheet if needed)					