


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 14	Township number T 25 S R	Range number 29 ^W
2. Distance and direction from nearest town or city 50 1/2 North Street address of well location if in city:			3. Name of well: Edborn Nelson R.R. or street: P.O. Box 473 City, state, zip code: Cimarron KS 67835		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 7-31-76 Well depth 330 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 330 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 298 ft. and 318 ft. eff. 157-298 ft. and 318-330 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 2" Down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 131 ft. below land surface Date 6-22-76		
			12. Pumping level below land surfaces: 166 ft. after 2 hrs. pumping 725 g.p.m. 182 ft. after 4 hrs. pumping 1025 g.p.m. Estimated maximum yield 1025 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goolds US Pumps Model number 12 JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 240 ft. capacity 1000 Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. <input type="checkbox"/> Address P.O. Box A Garden City, KS Signed <i>[Signature]</i> Date 9-22-76 Authorized representative		

76
76
25290
14 NW SE NW
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Ted Nelson
Gray County
5-20-76

Location: 650' North of SW $\frac{1}{4}$ Pivot, 1 $\frac{1}{2}$ North of Ingalls Feed-
lot 14-25-29
Wants well 20-30' North of Test

0	3	Top soil
3	108	Tan clay
108	149	Fine to med. sand & gravel
149	157	Tan clay
157	218	Fine to med. sand
218	238	Med. to coarse sand & gravel (loose)
238	247	Tan clay
247	258	Fine to med. sand
258	263	Tan clay
263	287	Fine med. sand & gravel
287	298	Tan clay
298	318	Fine to med. sand & gravel
318	322	Mixed colored clay
322	330	Fine to med. sand
330	343	Mixed colored clay
343	350	Shale

Static Water Level: 130

F.D. - 330'XXX
20' Screen