


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

25
29W26SESENW
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Gray	Logan	SE $\frac{1}{4}$ NW $\frac{1}{4}$	#26	T #25 S	R #29 W
Distance and direction from nearest town or city: Ingalls on highway 50			2 miles NE$\frac{1}{4}$ of west	3 Owner of well: Richard Phillips 6635 Grosvenor Place Indianapolis, Indiana 46220		
Street address of well location if in city:				4 Well depth: 251 ft. Date of completion 6-24-75 Well diameter 8 in.		
Locate with "X" in section below: N			Sketch map: 	E of #26 T#25W R #29N	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
2	Type and color of material			From	To	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
	Top soil & fine sandy clay			0	15	7 Casing: Material RMP Height: above ground Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 251 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight lbs./ft. — in. to ft. depth
	Clay & fine sand mixed			15	30	8 Screen: Manufacturer Sunflower Type RMP Dia. 5" Slot/gauge 1/8" Length 20 ft. Set between 230 ft. and 251 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1"
				30	45	9 Static water level: 99 ft. below land surface Date 6-24-75
	Fine sand			45	60	10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
	Fine to medium sand			60	90	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
	Fine sand & clay mixed			90	105	12 Well head completion: None <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
	Medium sand			105	135	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From ft. to ft.
	Medium sand & clay			135	155	14 Nearest source of possible contamination: ft. 5 mile direction West Type 1st Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	Clay			150	165	15 Pump: Windmill <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
	Clay & fine sand			165	180	
	Fine to medium sand			180	195	
	Fine sand & clay			195	225	
	Fine to medium sand			225	240	
	Medium to coarse sand & clay			240	255	
	Clay & sand - 3ft. rock			255	275	
16	Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
	(use a second sheet if needed)					
17	Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name Box 174 Cimarron, Ks. License No. Address Box 174 Cimarron, Ks. Signed Joe Crick Date 8-29-75 Authorized representative					