

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:	County	Fraction	Section number	Township number	Range number
X	Gray	SW 1/4 SW 1/4 SW 1/4	27	T 25	S R 29 W E/W
X. Distance and direction from nearest town or city: 2 1/2 miles of Ingalls X south into Street address of well location if in city: pasture			3. Owner of well: R.R. or street: City, state, zip code: Norbert Irsik Ingalls, Kansas 67853		
4. Locate with "X" in section below: N			Sketch map:		
			6. Bore hole dia. 9 1/8 in. Completion date _____ Well depth 64 ft. 5-22-78		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 5 in. RMP 100 PVC XX Weight 2.8 lbs./ft. Dia. 5 in. to 64 ft. depth Wall Thickness: inches or Dia. 5 in. to ft. depth gage No. 265		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5" Slot/groove fine Length 40' Set between 24 ft. and 64 ft. ft. and ft. Gravel pack? Yes Size range of material 1/64-5/32
Top soil			0	3	11. Static water level: 8 ft. below land surface Date 5-19-78
Med. sand			3	10	12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 200 g.p.m.
Med. to lar. sand & gravel			10	66	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Clay			66	70	14. Well head completion: 3/4" Pitless adapter 3/4" inches above grade
					15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 7 ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type river Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Tower & Mill Model number _____ HP _____ Volts _____ Length of drop pipe 42 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation: river bottom Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
					19. Remarks:
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name _____ License No. _____ Address Meade, Kansas 67864 Signed John Friesen Date 6-5-78 Authorized representative _____