

USE TYPEWRITER OR BALL
POINT-PEN-PRESS-FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction NW 1/4 SE 1/4 NE 1/4	Section number 31	Township number T 25 S R	Range number 29 EW			
2. Distance and direction from nearest town or city: 1/2 S., 3/4 E., 1/2 S., 1/2 E. of the			3. Owner of well: Don Renick (#65)						
Street address of well location if in city: Charleston Bridge			R.R. or street: Ingalls, Ks. 67853						
4. Locate with "X" in section below:			Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>2-27-77</u> Well depth <u>196</u> ft.			
						7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material			From			To			9. Casing: Material <u>steel</u> Height: Above <u>grade</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>197</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>250</u>
									10. Screen: Manufacturer's name <u>Johnson</u> Type <u>galv.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>20</u> ft. Set between <u>170</u> ft. and <u>190</u> ft. Perf: 60-170 ft. and 190-196 ft. Gravel pack? <u>Yes</u> Size range of material <u>5" down</u>
						11. Static water level: <u>27</u> ft. below land surface Date <u>2-24-77</u> mo./day/yr.			
						12. Pumping level below land surfaces: <u>49</u> ft. after <u>2</u> hrs. pumping <u>1000</u> g.p.m. <u>61</u> ft. after <u>4</u> hrs. pumping <u>1500</u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.			
						13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>			
						14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter			
						15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
						16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
						17. Pump: <u>Not installed</u> Manufacturer's name <u>Customer's</u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
						(Use a second sheet if needed)			
18. Elevation:		19. Remarks:							
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. <u> </u> Address <u>Box A Garden City, Ks.</u> Signed <u>[Signature]</u> Date <u>11-28-77</u> Authorized representative							

T 25 29E
 R 31
 Sec 1/4 NE SE NE
 1/4 1/4 NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 . . . P.O. Box A . . . GARDEN CITY, KANSAS 67846

DON RENICK
GRAY COUNTY
1/27/77

Location: NE 31-25-39 30 Ft. west of pivot
Static Water Level- 30'

Test #3

0	10	Top soil
10	19	Med. course gravel
19	31	Brown sandy clay Hard
31	80	Fine to med. sand and gravel Loose
80	99	Brownish yellow clay
99	107	Fine to med. sand and gravel Loose
107	142	Brown sandy clay
142	160	Fine sand 30% clay Loose
160	173	Fine to med. sand and small clay streak
173	192	Med. course gravel yellow brown rock Loose
192	194	Yellow clay
194	196	Shale

T.D. 196