

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Gray County</b>	Section <b>NE 1/4 SW 1/4</b>	Section number <b>31</b>	Township number <b>T 25</b>	Range number <b>S R 29</b>	
2. Distance and direction from nearest town or city:	<b>1 East of Charleston</b>					
Street address or well location if in city:	<b>on Hwy 50, 2½ South</b>					
3. City, state, zip code:	<b>Ingalls, KS 67853</b>					
4. Locate with "X" in section below:		Sketch map:				
5. Type and color of material		From	To	6. Bore hole dia. <b>26</b> in. Completion date <b>12-29-78</b> Well depth <b>200</b> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia <b>16</b> in. to <b>200</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.219</b>		
				10. Screen: Manufacturer's name <b>Johnson</b> <b>Johnson Screen 100-160</b> <b>Slot/gauze 100 Plain 100-165 Perf.</b> Set between <b>165-195 Gauze</b> ft. <b>195 - 200 Perf.</b> ft. Gravel pack <b>yes</b> Size range of material <b>1 to 5/8</b>		
				11. Static water level: <b>43</b> ft. below land surface Date <b>10-31-78</b> mo./day/yr.		
				12. Pumping level below land surfaces: <b>92</b> ft. after <b>2</b> hrs. pumping <b>1350</b> g.p.m. <b>103</b> ft. after <b>4</b> hrs. pumping <b>1750</b> g.p.m. Estimated maximum yield <b>1750</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft</b> inches above grade		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: ft. Direction <b>NE</b> Type <b>None</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Sealed 4 stag. 12" Pump</b> Model number <b>140</b> HP <b>1/2</b> Volts <b>115</b> Length of drop pipe <b>140</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation: 19. Remarks:  Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Winter-Wilcox Drilling Co. 200</b> Business name <b>Winter-Wilcox Drilling Co. 200</b> Address <b>Box A, Garden City, KS 67853</b> Signed <b>John A. Wilcox</b> Date <b>12-7-78</b> Authorized Representative <b>John A. Wilcox</b>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

# MINTER-WILSON DRILLING CO.

INCORPORATED

Phone 276-3269 • P.O. Box A • GARDEN CITY, KANSAS 67050

September 13, 1978

Don Renick  
Gray County

Location: S. W.  $\frac{1}{4}$  31-25-29 30 ft. East of Pivot

Static Water Level: 50

Test #1

0	1	Top Soil
1	5	Fine Sand
5	34	Fine to med. sand and gravel (loose)
34	50	Brown Sandy Clay
50	56	Fine to med. sand and gravel
56	62	Brown Sandy Clay
62	69	Fine to med. sand and gravel mixed with cemented stone hard
69	88	Brown Sandy Clay
83	95	Fine Sand (loose)
95	103	Fine to med. sand and fine gravel (loose)
103	107	Brownish Clay streak of coarse Gravel (loose)
107	117	Brownish Clay
117	124	Fine to med. sand and gravel (loose)
124	143	Brown Sandy Clay
143	155	Brown Clay small streak of Fine Sand (loose)
155	161	Brown Clay
161	170	Fine to med. sand and gravel (loose)
170	182	Fine to med. sand and gravel 10% Clay (loose)
182	198	Fine to med. sand and gravel with mixed yellow Rock
198	204	Yellow Clay Shale Hard

T. D. 200