

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray County	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 32	Township number T 25 S R 29 E/W	Range number 29
2. Distance and direction from nearest town or city:	2 1/2 East of Charleston		3. Owner of well: Don Renick	R.R. or street: Ingalls, KS 67853	
4. Locate with "X" in section below:			Sketch map:		
			6. Bore hole dia. 26 in. Completion date 12-29-78 Well depth 285 ft.		
5. Type and color of material			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 285 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name Johnson Typ. Johnson Screen D100-16" Slot/gauze 8-100 Plain 100-140 perf. Set between 140-170 Screen 170-180 perf. 180-190 Screen 190-205 Perf. ft. Gravel pack? yes Size range of material 3/8 to 5/8		
			<input checked="" type="checkbox"/> Static water level: 57 ft. below land surface Date 11-13-78 mo./day/yr.		
			12. Pumping level below land surfaces: 98 ft. after 2 hrs. pumping 900 g.p.m. 104 ft. after 4 hrs. pumping 1125 g.p.m. Estimated maximum yield 1125 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			<input checked="" type="checkbox"/> Nearest source of possible contamination: ft. _____ Direction N/A Type _____ <input checked="" type="checkbox"/> Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Condit 4 stg. 12" Bore Model number _____ HP _____ Volts _____ Length of drop pipe 140 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drilling Co. 299 Business name License No. _____ Address Box A, Garden City, KS 67844 Signed Don Renick Date 12-29-78 Authorized representative		

25 29 W 32 NWSESW
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Drillers **MINTER-WILSON DRILLING CO.**
INCORPORATED

Drilling
and
Well
Work
Complex
and
Repairing

Phone 276-8269 • P.O. Box 7 • GARDEN CITY, KANSAS 67846

October , 1978

Don Renick
Gray County

Location: S. W. $\frac{1}{4}$ 32-25-29 1000 ft. South of Pivot
Static Water Level - 40
Test #

0	1	Top Soil
1	11	Fine Sand
11	18	Fine to med. sand and gravel (loose)
18	56	Brown Sandy Clay
56	61	Fine to med. sand and fine gravel
61	69	Cemented sand stone tight
69	86	Brown Sandy Clay
86	94	Fine to med. sand and gravel (loose)
94	108	Brownish Yellow Clay
108	120	Fine to med. sand and gravel (loose)
120	142	Brown Clay
142	170	Fine to med. sand and gravel (loose)
170	177	Fine to med. sand (loose)
177	182	Brown Sandy Clay Hard Pull Down
182	185	Fine to med. sand and gravel (loose)
185	192	Med. sand to med. coarse gravel mixed with Yellow Rock (loose)
192	199	Brown Sandy Clay
199	202	Med. Sand to med. coarse gravel (tight)
202	204	Yellow Clay Hard
204	206	Shale

T. D. 205