


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

2530 W 15 NW NW SW
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Logan NW NW SW¹	Fraction	Section number S# 15	Town number T #25 S	Range number R #30 W
Distance and direction from nearest town or city: 2 miles west of Charleston and 1/2 north Street address of well location if in city:			3 Owner of well: Mike Mooney Address: Ingalls, Kansas 67853			
Locate with "X" in section below: 			Sketch map: NW¹ of the NW¹ of the SW¹ of Section #15 T#25 R#30			
4 Well depth: 268 ft. Date of completion 6-5-75 Well diameter 8 in.						
5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary						
6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well						
7 Casing: Material RMP Height: above 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 268 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to ft. depth						
8 Screen: Manufacturer Sunflower Type RMP Dia. 5" Slot/gauge 1/8" Length 20 ft. Set between 245 ft. and 265 ft.						
9 Static water level: 98 ft. below land surface Date 6-5-75						
10 Pumping level below land surfaces: 125 ft. after 15 hrs. pumping 30 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 60 g.p.m.						
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date						
12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade						
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 5 ft. to 15 ft.						
14 Nearest source of possible contamination: ft. 100 Direction SE Type Swiver Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
15 Pump: Not installed Manufacturer's name Flint & Walling Model number 7BA12 HP 3/4 Volts 230 Length of drop pipe 150 ft. capacity 10 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
16 Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name Box 174 Cimarron, Ks. License No. Address Box 174 Cimarron, Ks. Signed Tommy Clegg Date 9-4-75 Authorized representative						