


## WATER WELL RECORD

Form WWC-5

KSA 82a-1212

1 LOCATION OF WATER WELL		Fraction 1/4 SW 1/4 SE 1/4		Section Number 22	Township Number T 25 S	Range Number R 30 E 1/4			
County: Gray									
Distance and direction from nearest town or city? Charleston 1 West - 1/2 South - 1/2 West			Street address of well if located within city?						
2 WATER WELL OWNER: Renick Bros. #67						Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box # : Ingalls, KS 67853						Application Number:			
3 DEPTH OF COMPLETED WELL 150 ft. Bore Hole Diameter 26 in. to 150 ft., and in. to ft.									
Well Water to be used as: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well									
Well's static water level 17 ft. below land surface measured on April month 28 day 1982 year									
Pump Test Data: Well water was 80 ft. after 2 hours pumping 1300 gpm Est. Yield 1515 gpm: Well water was 105 ft. after 3 hours pumping 1515 gpm									
4 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded X 2 PVC 4 ABS 7 Fiberglass Threaded									
Blank casing dia 16 in. to 150 ft. Dia in. to ft. Dia in. to ft.									
Casing height above land surface 12 in. weight 13.6 lbs./ft. Wall thickness or gauge No. 219									
TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)									
Screen or Perforation Openings Are: 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)									
Screen-Perforation Dia 16 in. to 150 ft. Dia in. to ft. Dia in. to ft.									
Screen-Perforated Intervals: <del>xx</del> Screen 80-100 ft. <del>xx</del> Perf 100-125 ft. <del>xx</del> Screen 125-145 ft. <del>xx</del> Perf 145-150 ft.									
From. ft. to ft. From. ft. to ft. From. ft. to ft. From. ft. to ft.									
Gravel Pack Intervals: From. 10 ft. to 150 ft. From. ft. to ft. From. ft. to ft. From. ft. to ft.									
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grouted Intervals: From. 0 ft. to 10 ft. From. ft. to ft. From. ft. to ft. From. ft. to ft.									
What is the nearest source of possible contamination: 10 Fuel storage 14 Abandoned water well 1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well 2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below) 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines N/A Center of 1/4 Section									
Direction from well How many feet ? Water Well Disinfected? Yes No X Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year: Pump Installed? Yes X No If Yes: Pump Manufacturer's name Used customers pump Model No. HP 100 Volts Depth of Pump Intake 120 ft. Pumps Capacity rated at gal/min.									
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on May month 31 day 1982 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208 This Water Well Record was completed on June month 17 day 1982 year under the business name of Minter Wilson Drilling Co., Inc. by (signature) <i>M. Minter Wilson</i>									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG		FROM	TO	LITHOLOGIC LOG	
									
Test log attached									
ELEVATION:									
Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft. 4 ft.							(Use a second sheet if needed)		
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

RENICK BROS.  
Gray County  
April 6, 1982

Location: Southwest corner of Circle 67

Static Water Level - 20

Test #

0	7	Sand
7	33	Coarse Gravel
33	47	Brown Clay
47	67	Clay & White Rock (Hard)
67	80	Brown Clay
80	100	Fine to Medium Sand & Gravel 10% Clay (Loose)
100	125	Brown Clay
125	144	Fine to Medium Sand & Gravel 10% Clay
144	164	Brown Clay Gray & Yellow
164	170	Shale (Hard)

TD 150'