


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Logan	Fraction Mid. of SE 1/4	Section number 26	Town number TS 25	Range number RW 30
Distance and direction from nearest town or city: 1 mile south, 1 west of Charleston, Ks.			3 Owner of well: Don Renick Address: Ingalls, Ks.			
Locate with "X" in section below: Sketch map: 						
4 Well depth: 175 ft. Date of completion 1-26-75 Well diameter 26 in.						
5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well						
7 Casing: Material St Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 34 in. Weight 25 lbs./ft. in. to ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth						
8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot/gauge 1/4 in. 100 Length 20' Set between 140 ft. and 150 ft. 155-165 Perf.: 35-140, 150-155, 160-170 Gravel pack <input type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 7-10 mm down						
9 Static water level: 23 ft. below land surface Date 1-29-75						
10 Pumping level below land surfaces: 34 ft. after 2 hrs. pumping 901 g.p.m. 42 ft. after 4 hrs. pumping 1315 g.p.m. Estimated maximum yield 1200 g.p.m.						
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____						
12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade						
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Puddled Depth: From 0 ft. to 10 ft.						
14 Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
15 Pump: <input type="checkbox"/> Not installed Manufacturer's name FMC-Peerless Model number 3786 HP _____ Volts _____ Length of drop pipe 120 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
16 Remarks: elevation Electric motor. (We did not sell, so don't know volts or horsepower) Good well. No possible contamination.						
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilg. Co. 208 Business name _____ License No. _____ Address Box 493 Garden City, Ks. Signature John Minter Date 3-14-75 Authorized representative						

Forward the white, blue and pink copies to the Kansas State Dept. of Health.

Form WWC-5