

USE TYPEWRITER OR BALL  
POINT PEN. PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Gray</b>	Fraction <b>SW 1/4 NE 1/4 SE 1/4</b>	Section number <b>29</b>	Township number <b>T 25 S</b>	Range number <b>R 30 E</b>				
2. Distance and direction from nearest town or city: <b>5 south, 2 east, 1 1/2 north of Pierceville.</b>			3. Owner of well: <b>Wartman Bros.</b> R.R. or street: <b>% Jack Wartman</b> City, state, zip code: <b>Pierceville, Ks. 67868</b>						
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W <table border="1" style="display: inline-table; vertical-align: middle;"><tr><td>NW</td><td>NE</td></tr><tr><td>SW</td><td>SE</td></tr></table> E S 1 Mile</div>			NW	NE	SW	SE	Sketch map: <div style="text-align: center;">1 Mile</div>		
NW	NE								
SW	SE								
5. Type and color of material			6. Bore hole dia. <b>26</b> in. Completion date <b>5-17-77</b> Well depth <b>194</b> ft.						
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other						
			9. Casing: Material <b>steel</b> Height: Above <del>surface</del> <b>12</b> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>195</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>250</b>						
			10. Screen: Manufacturer's name <b>Johnson</b> Type <b>galv.</b> Dia. <b>16"</b> Slot/ <del>size</del> <b>10</b> ft. Length <b>10</b> ft. Set between <b>130-140</b> ft. and <b>170-180</b> ft. Perf: <b>70-130</b> ft. and <b>140-170</b> ft. <b>194</b> Gravel pack? <b>yes</b> Size range of material <b>1/2" down</b>						
			11. Static water level: <input type="checkbox"/> mo./day/yr. <b>28</b> ft. below land surface Date <b>4-19-77</b>						
			12. Pumping level below land surfaces: <b>55</b> ft. after <b>2</b> hrs. pumping <b>900</b> g.p.m. <b>72</b> ft. after <b>4</b> hrs. pumping <b>1450</b> g.p.m. Estimated maximum yield <b>1450</b> g.p.m.						
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>						
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade						
			15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.						
16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No									
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Goulds - US Pump</b> Model number <b>12JMO</b> HP <b>80</b> Volts <input type="checkbox"/> Length of drop pipe <b>140</b> ft. capacity <b>1200</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other									
18. Elevation:			19. Remarks: <div style="text-align: center;">(Use a second sheet if needed)</div>						
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name License No. <input type="checkbox"/> Address <b>Box A Garden City, Ks.</b> Signed <i>[Signature]</i> Date <b>7-25-77</b> Authorized representative									

Forward the white, blue and pink copies to the Department of Health and Environment

*Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

WARTMAN BROS.  
GRAY COUNTY  
3-4

Location: SE 29-25-30 Pivot  
Static Water Level- 35'  
Test #8

0	3	Top soil
3	11	Fine sand
11	110	Fine to med. sand and gravel
110	125	Brown clay
125	146	Fine to med. sand and gravel
146	167	Brown clay
167	194	Fine to med. sand and gravel
194	197	Yellow clay and white rock
197	200	Shale