


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray County	Fraction 1/4 C 1/4 NE 1/4	Section number 30	Township number T 25 S R 30 E W
2. Distance and direction from nearest town or city: 4 West of Charleston, 1 1/2 South, 1/4 West Street address of well location if in city:			3. Owner of well: Dale Corley R.R. or street: 114 W. Pine City, state, zip code: Garden City, KS 67846		
4. Locate with "X" in section below:		Sketch map:			
					
5. Type and color of material		From	To	6. Bore hole dia. 26 in. Completion date 12-21-78 Well depth 190 ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 190 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219	
				10. Screen: Manufacturer's name Johnson Type Johnson Galy Dia 100-16" Slot/gauze 0-00 Plain 100-160 Perf. Set between 160-180 Screen 180-190 Perf. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 3 to 5/16	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 45 ft. below land surface Date 12-21-78	
				12. Pumping level below land surfaces: 80 ft. after 2 hrs. pumping 900 g.p.m. 87 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Could 4 stg. 12" 1 hp Model number <input type="checkbox"/> HP 100 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. Address Box A, Garden City, KS Signed Minter Wilson Date 5/30/79 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CORLEY GIGOT

GRAY - FINEY COUNTY
10-13-76

Location: NE 30-25-30 30 Ft. west of pivot
Static Water Level- 40'

Test #5 Pivot 11

0	1	Top soil
1	3	Fine sand
5	9	Fine to med. sand
9	21	Coarse gravel
21	38	Brown sandy clay
38	75	Fine to med. sand and gravel
75	63	Fine to med. sand and gravel mixed with rock tight
63	94	Brown clay 15" loose gravel layer
94	116	Brownish yellow clay clay
116	120	Fine to med. sand and gravel
120	128	Brown clay
128	134	Fine to med. sand
134	143	Brown sandy clay
143	166	Brown clay
166	170	Fine to med. sand and gravel
170	187	Med. coarse gravel white and yellow rock loose
187	190	Yellow clay
190	195	Shale