


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 32	Township number T 25 S	Range number R 30 E
2. Distance and direction from nearest town or city: 4 south, 1 1/2 east, 1/2 north of Pierceville.			3. Owner of well: Wartman Bros. R.R. or street: % Jack Wartman City, state, zip code: Pierceville, Ks. 67868		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. 26 in. Completion date 5-11-77 Well depth 201 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 202 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
			10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauze 10 ft. Length 10 ft. Set between 160-170 ft. and 180-190 ft. Perf: 70-160 ft. and 170-180-190-201 ft. Gravel pack? yes Size range of material 1/2" down		
			11. Static water level: 46 ft. below land surface Date 4-28-77 mo./day/yr.		
			12. Pumping level below land surfaces: 59 ft. after 2 hrs. pumping 900 g.p.m. 70 ft. after 4 hrs. pumping 1700 g.p.m. Estimated maximum yield 1700 g.p.m.		
			13. Water sample submitted: no./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
			14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: Not installed Manufacturer's name Goulds - US Pump Model number 12JLMO HP 75 Volts Length of drop pipe 140 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Address Box A Garden City, Ks. Signed [Signature] Date 7-25- Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The
Proprietors*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

WARTMAN BROS.
GRAY COUNTY
3/3/77

Location: SW 32-25-30 Pivot

Static Water Level- 35'

Test #5

0	5	Fine sand
5	11	Brown clay
11	171	Fine to med. sand and gravel
171	183	Brown clay
183	201	Fine to med. sand and gravel
201	212	Yellow and brown clay and white rock
212	215	Shale

T.D. 201