

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE 1/4 NW 1/4 SW 1/4	Section number 34	Township number T 25 S R 30	Range number W
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/2 south, 1 1/2 west, 3/4 west of Charleston.		3. Owner of well: R.R. or street: City, state, zip code: Don Renick Ingalls, Ks. 67853		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 26 in. Completion date 11-1-76 Well depth 295 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 in. to 296 ft. depth Wall Thickness: inches or Dia. 16 in. to 296 ft. depth 1/8 in. gage No. 250		
			10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/ 1/8" Length 20 ft. Set between 155 ft. and 175 ft. Perf: 90-155 ft. and 175-295 ft. Gravel pack? yes Size range of material 1/4" down		
			11. Static water level: 71 ft. below land surface Date 10-31-76		
			12. Pumping level below land surfaces: 94 ft. after 3 hrs. pumping 1350 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1350 g.p.m.		
			13. Water sample submitted: no mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 10-31-76		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: Manufacturer's name Customer's Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. 11-28-77 Authorized representative John Minter		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON RENICK
GRAY COUNTY
10-7-76

Location: SW $\frac{1}{4}$ 34-25-30 1 $\frac{1}{2}$ south 1 $\frac{1}{2}$ west 3/4 west of
Charle~~ton~~
Static Water Level- 55'

Test #1

0	7	Fine sand
7	35	Brown clay
35	82	Fine to med. sand and gravel Loose stks. coarse gravel
82	93	Brown clay
93	110	Fine to med. sand and gravel Loose
110	120	Brown clay
120	178	Fine to med. sand and gravel Loose
178	189	Brown clay and white rock tight
189	196	Fine to med. sand and gravel Loose
196	209	Brown clay
209	217	Fine to med. sand and gravel Loose
217	232	Brown clay
232	245	Fine to med. sand and fine gravel Loose
245	277	Brown clay
277	291	Fine to med. sand and gravel with white rock 10% clay tight
291	295	Brown clay and white rock Hard
295	300	Shale hard

T. D. 295'

1-copy of log