


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 SE 1/4 NE 1/4	Section number 34	Township number T 25	Range number S 30	EW E
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/2 south, 1 1/2 west, 1 1/2 south of Charleston.			3. Owner of well: Don Renick (#61) R.R. or street: Inggalls, Ks. 67853 City, state, zip code:		
4. Locate with "X" in section below:	Sketch map: 			6. Bore hole dia. 26 in. Completion date 2-3-77 Well depth 216 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				9. Casing: Material steel Height: Above 23555 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 217 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 1/2" Length 20 ft. Set between 170 ft. and 190 ft. Perf: 80-170 ft. and 190-216 ft. Gravel pack? yes Size range of material 1/2" down				11. Static water level: 57 ft. below land surface Date 1-28-77 mo./day/yr.		
12. Pumping level below land surfaces: 89 ft. after 2 hrs. pumping 800 g.p.m. 115 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Customer's Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name _____ License No. _____ Address Box A Garden City, Ks. Signed LeRoy Minter Date 11-28-77 Authorized representative _____		

Bo
- Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON RENICK
GRAY COUNTY
10-8-76

LOCATION: NE^{1/4} 34-25-30
STATIC WATER LEVEL 55'

TEST #3

0	17	Fine sand
17	32	Med. to coarse gravel Loose
32	65	Brown clay
65	71	Fine to med. sand and gravel Loose
71	80	Brown clay
80	95	Fine to med. sand and gravel Loose
95	104	Brown clay
104	146	Fine to med. sand and gravel Loose
146	155	Brown clay
155	170	Fine to med. sand and fine gravel Loose
170	187	Fine to med. sand and gravel 10% clay Loose
187	216	Brown clay and white rock tight
216	220	Shale hard

T.D. 187'
216'

1 - copy log