

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 34	Township number T 25	S R S 30 E	Range number EW	
2. Distance and direction from nearest town or city:	1/2 south, 1/4 west,		3. Owner of well:	Don Renick (#62)			
Street address of well location if in city:	3/4 south of Charleston		R.R. or street:	Ingalls, Ks. 67853			
4. Locate with "X" in section below:	<p>Sketch map:</p>						
5. Type and color of material	From	To	<p>6. Bore hole dia. 26 in. Completion date 2-1-77 Well depth 216 ft.</p>				
			<p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p>				
			<p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p>				
			<p>9. Casing: Material steel Height: Above or base Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 in. to 217 ft. depth Wall Thickness: inches or Dia. 16 in. to 217 ft. depth Wall Thickness: inches or Dia. 16 in. to 217 ft. depth Gage No. 250</p>				
			<p>10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 180 ft. and 200 ft. Perf: 80-180 ft. and 200-216 ft. Gravel pack? yes Size range of material 3" down</p>				
			<p>11. Static water level: 46 ft. below land surface Date 1-31-77</p>				
			<p>12. Pumping level below land surfaces: 63 ft. after 2 hrs. pumping 900 g.p.m. 71 ft. after 4 hrs. pumping 1350 g.p.m. Estimated maximum yield 1350 g.p.m.</p>				
			<p>13. Water sample submitted: no Date 1-31-77 Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p>				
			<p>14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade</p>				
			<p>15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.</p>				
			<p>16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>				
			<p>17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Customer's Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p>				
18. Elevation:	<p>(Use a second sheet if needed)</p>						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Topography:							<p>Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box A Garden City, Ks. Signed John Minter Date 6/78/66 Authorized representative John Minter Date 11-28-77</p>

Revised
Approved

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

BONN RENICK
GRAY COUNTY
10-1-76

LOCATION: SE^{1/4} 34-25-30
STATIC WATER LEVEL 55'

Test #2

0	11	Fine sand
11	28	Brown clay
28	52	Med. to coarse gravel Loose
52	72	Brown clay
72	140	Fine to med. sand and gravel Loose
140	153	Fine to med. sand and gravel 10% clay Loose
153	169	Brown clay
169	200	Fine to med. sand and gravel 10% clay Loose
200	206	Brown sandy clay
206	216	Fine to med. sand and gravel with white rock 10% clay Loose
216	224	Brown and yellow clay tight
224	230	Shale hard

T.D. 116'
216'

2 copies of log