


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

|  |  |  |  |   |                                       |                           |
|--|--|--|--|---|---------------------------------------|---------------------------|
| 1. Location of well:   |  | County<br><b>GRAY</b>  | Fraction<br><b>NW SE</b><br><del>NE</del> <del>SW</del> <b>1/4 NE</b> <b>1/4</b> | Section number<br><b>35</b>   | Township number<br><b>T 25 S R 30</b> | Range number<br><b>30</b> |
| 2. Distance and direction from nearest town or city: <b>1 3/4 south of Charleston 3/4 west</b><br>Street address of well location if in city:  |  |  |  | 3. Owner of well: <b>Don Renick</b><br>R.R. or street: <b>(# 56)</b><br>City, state, zip code: <b>Ingalls, Ks. 67853</b>  |                                       |                           |
| 4. Locate with "X" in section below:<br>   |  |  |  | Sketch map:   |                                       |                           |
| 5. Type and color of material  |  |  |  | 6. Bore hole dia. <b>26</b> in. Completion date <b>4-20-76</b><br>Well depth <b>210</b> ft.   |                                       |                           |
|  |  |  |  | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug<br><input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary   |                                       |                           |
|  |  |  |  | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry<br><input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock<br><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other  |                                       |                           |
|  |  |  |  | 9. Casing: Material <b>steel</b> Height: Above or below<br>Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in.<br>RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft.<br>Dia. <b>16</b> in. to <b>21</b> ft. depth Well thickness: inches or<br>Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth page No.    |                                       |                           |
|  |  |  |  | 10. Screen: Manufacturer's name<br><b>Johnson Division</b><br>Type <b>GALV.</b> Dia. <b>16"</b><br>Slot/gauze <b>100</b> Length <b>20'</b><br>Set between <b>170-180</b> ft. and <b>190-200</b> ft.<br>Perf. <b>75-170</b> ft. and <b>180-190</b> ft. and <b>200-210</b> ft.<br>Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/8" Down</b>  |                                       |                           |
|  |  |  |  | 11. Static water level: <input type="checkbox"/> mo./day/yr.<br><b>34</b> ft. below land surface Date <b>3-11-76</b>  |                                       |                           |
|  |  |  |  | 12. Pumping level below land surfaces:<br><b>71</b> ft. after <b>3</b> hrs. pumping <b>1325</b> g.p.m.<br><input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.<br>Estimated maximum yield <b>1325</b> g.p.m.  |                                       |                           |
|  |  |  |  | 13. Water sample submitted: <input type="checkbox"/> mo./day/yr.<br>Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date  |                                       |                           |
|  |  |  |  | 14. Well head completion:<br><input type="checkbox"/> Pitless adapter <b>12</b> inches above grade  |                                       |                           |
|  |  |  |  | 15. Well grouted? <b>yes</b><br>With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete<br>Depth: From <b>0</b> ft. to <b>10</b> ft.   |                                       |                           |
| 16. Nearest source of possible contamination: <b>N/A</b><br>ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/><br>Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |  |  |  | 17. Pump:<br>Manufacturer's name <b>Boulds US Pump</b><br>Model number <b>12 IHMO</b> HP <b>75</b> Volts<br>Length of drop pipe <b>160</b> ft. capacity <b>1000</b> g.p.m.<br>Type:<br><input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine<br><input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating<br><input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |                                       |                           |
| 18. Elevation:   |  | 19. Remarks:<br><b>Drilling done by Central Well &amp; Pump<br/>Pratt, Ks.</b> |  | 20. Water well contractor's certification:<br>This well was drilled under my jurisdiction and this report<br>is true to the best of my knowledge and belief.<br><b>Minter Wilson Drilling 208</b><br>Business name <b>P.O. Box a Garden City, Ks.</b><br>Address <b>8-12-76</b><br>Date <b>8-12-76</b><br>Authorized representative   |                                       |                           |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON RENICK  
GRAY COUNTY  
1-20-76

Location NE 35-25-30  
½ Mile West From Pivot 55, Pivot 56  
30 West of Pivot

Static Water Level 50'

## Test #2

|     |     |   |
|-----|-----|---|
| 0   | 1   | Top Soil  |
| 1   | 10  | Fine Sand   |
| 10  | 40  | Med. Coarse Gravel                                      |
| 40  | 54  | Brown Sandy Clay  |
| 54  | 62  | Fine To Med. Sand & Gravel                              |
| 62  | 74  | Brown Sandy Clay  |
| 74  | 80  | Fine To Med. Sand & Gravel (10%) Clay                   |
| 80  | 98  | Brown Sandy Clay, Gravel Streak                         |
| 98  | 127 | Fine To Med. Sand & Gravel (10%) Clay                   |
| 127 | 134 | Brown Sandy Clay  |
| 134 | 138 | Med. Sand & Gravel                                      |
| 138 | 155 | Brown Sandy Clay  |
| 165 | 183 | Fine To Med. Sand & Gravel (10%) Clay<br>Streak (Tight) |
| 183 | 194 | Brown Sandy Clay  |
| 194 | 206 | Med. Sand & Gravel Mixed with Rock (Loose)              |
| 206 | 209 | Yellow Clay   |
| 209 | 211 | Shale   |

210  
206 TD  
20 Screen ?