

CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction (1/4 1/4 1/4) Section-Township-Range changed:

listed as _____

changed to _____

Other changes: Initial statements: Finney County

Changed to: Gray County

Comments: _____



verification method: Written & Legal Description, and
Piercerville SW 1:24,000 topo- map. initials: PL date: 8/27/29

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 6620

1. Location of well:	County	Fraction	Section number	Township number	Range number			
	FINNEY	SE NW 1/4 NW 1/4	32	T 25	S R 30 SW			
2. Distance and direction from nearest town or city:	South of Piercleville to first curve 1 1/2 east 1/2 north							
3. Owner of well:	Lonnie Wartman R.R. or street: Ingallx, Ks.							
4. Locate with "X" in section below:	Sketch map: 							
5. Type and color of material	From	To	6. Bore hole dia. 26 in. Completion date 4-30-76 Well depth 221 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 22 ft. depth Wall Thickness: inches or Dia. 16 in. to 22 ft. depth gage No. 219 <u>mc</u> 10. Screen: Manufacturer's name Johnson Division Type Galv Dia. 16" <u>mc</u> Slot/gauze 100 Length 20' Set between 160 ft. and 180 ft. 50 ft. to 160 ft. and 195-231 ft. Gravel pack? <input type="checkbox"/> Size range of material <u>all down</u> 11. Static water level: mo./day/yr. 20 ft. below land surface Date 4-27-76 12. Pumping level below land surfaces: 50 ft. after 3 hrs. pumping 1500 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m. 13. Water sample submitted: mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade 15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? Yes <input type="checkbox"/> No 17. Pump: Manufacturer's name Goulds US Pumps Model number 12JHO HP 100 Volts Length of drop pipe 110 ft. capacity 100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: Customer furnished motor Drilling done by central well & Pump Pratt, Ks. 			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name <u>P.O. Box A Garden City, Ks</u> Address <u>716-72</u> Signature <u>Minter Wilson</u> Date <u>7-16-76</u> Authorized representative		

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Owner
Lonnie ~~Shawton~~
Finney County
4-9-76

Location: Northeast of pivot NW $\frac{1}{4}$ 32-25-30

0	5	Top soil, fine sand
5	7	White sand, clay
7	52	Coarse gravel, loose
52	60	Med. coarse gravel, loose
60	71	Fine to med. sand and gravel
71	76	Brown sandy clay
76	83	Brown sandy clay, gravel streak
83	105	Fine to med. sand, gravel, loose
105	112	Fine to med. sand, some med. coarse gravel, loose
112	115	Brown sandy clay
115	127	Fine to med. sand and gravel
127	146	Brown sandy clay with rock, hard
146	157	Fine to med. sand, gravel
157	180	Med. coarse gravel, loose
180	186	Brown sandy clay, gravel streak
186	194	Fine sand
194	206	Brown sandy clay
206	217	Fine to med. sand, little tight
217	226	Fine to med. sand, 10% clay, little tight
226	231	Fine to med. sand, gravel with white rock, tight
231	235	Yellow and shale

Static Water Level: 35

T.D. 231'