

MINTER-WILSON DRILLING CO.
INCORPORATED

**Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing**

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

**Nelle Beach Trust
Corley Farms
Finney County
2-23-06**

Location: SE $\frac{1}{4}$ 25-25-31 - From Pierceville Bridge - 1 mile south,
 $\frac{1}{2}$ mile east, $\frac{3}{4}$ of a mile south &
 $\frac{1}{4}$ of a mile east to pivot
 - 80 ft. east of well

Static Water Level – 60 ft.

Test #1

0' to 1' - Top soil
1' to 10' - Fine sand - loose
10' to 14' - Brown clay
14' to 23' - Fine to medium sand & gravel
23' to 44' - Medium coarse gravel
44' to 55' - Brown sandy clay
55' to 87' - Fine to medium sand & gravel
87' to 99' - Cemented gravel - pull down 100
99' to 105' - Fine to medium sand & gravel
105' to 111' - Cemented gravel - hard pull down 500
111' to 127' - Brown yellow clay
127' to 135' - Fine to medium sand & gravel
135' to 139' - Brown clay
139' to 146' - Fine to medium sand & gravel
146' to 189' - Brown clay
189' to 204' - Fine to medium sand & gravel
204' to 207' - Yellow clay
207' to 215' - Shale