

17293

KSA 82a-1212

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Martin Nusser
Finney County
10-2-06

Location: SE $\frac{1}{4}$ 32-25-32 - Harry Lightner Corner on Hwy. 83 - 1 $\frac{1}{4}$ miles east,
 $\frac{1}{2}$ mile north, & $\frac{1}{4}$ mile west to well
 - offset - 40 ft. south & 80 ft. west

Static Water Level - 150 ft.

Test #2

0' to 1' - Top soil
1' to 18' - Brown sandy clay
18' to 21' - Brown clay
21' to 36' - Fine to medium sand & gravel
36' to 84' - Fine to medium sand & gravel with some coarse
84' to 110' - Fine to medium sand & gravel with clay streaks
110' to 156' - Brown sandy clay
156' to 179' - Brown clay
179' to 208' - Fine to medium sand & fine gravel
208' to 234' - Brown sandy clay
234' to 247' - Fine to medium sand - small clay streaks
247' to 284' - Brown sandy clay
284' to 291' - Fine to medium sand & fine gravel
291' to 325' - Brown sandy clay
325' to 358' - Fine to medium sand
358' to 379' - Brown clay
379' to 390' - Fine sand
390' to 404' - Brown sandy clay
404' to 410' - Fine sand & fine gravel
410' to 454' - Brown clay with gravel streaks
454' to 498' - Brown sandy clay - tight
498' to 500' - Fine to medium sand & gravel
500' to 508' - Brown clay with brown rock-40%
508' to 526' - Brown yellow clay - hard
526' to 530' - Shale - hard