

17013

KSA 82a-1212

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

• P.O. Box A

• GARDEN CITY, KANSAS 67846

Jim Staley
Finney County
10-26-06

Location: SE $\frac{1}{4}$ 35-25-32 - Lightner Trailer Park - 4 $\frac{1}{4}$ miles east,
3/4 of a mile south & $\frac{1}{4}$ mile west
- 81 ft. east of well

Static Water Level - Approx. 160 ft.

Test #1

0' to 1' - Top soil
1' to 19' - Brown clay
19' to 34' - Brown sandy clay
34' to 56' - Fine to medium sand & gravel
56' to 144' - Fine to medium sand & gravel with some coarse
144' to 192' - Brown clay
192' to 217' - Brown sandy clay
217' to 238' - Brown clay -- small gravel streaks
238' to 270' - Fine to medium sand & gravel
270' to 276' - Brown clay
276' to 305' - Fine to medium sand & gravel
305' to 327' - Brown sandy clay
327' to 342' - Fine to medium sand & gravel
342' to 351' - Fine to medium sand & gravel -- 10% clay
351' to 374' - Brown sandy clay - tight
374' to 408' - Fine to medium sand
408' to 415' - Brown clay
415' to 425' - Brown yellow clay