

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KEARNY	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 3	Township number T 25 S	Range number R 35 EW
2. Distance and direction from nearest town or city: Across river bridge at Deerfield Follow black top west approx. 4 miles 3/4 south 1/4 east				3. Owner of well: Triple T Farms R.R. or street: (Circle #3-3) City, state, zip code: Lakin, Ks 67860		
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. <u>26</u> in. Completion date <u>11-30-75</u> Well depth <u>330</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material <u>steel</u> Height: <u>Above</u> of below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36/87</u> lbs./ft. Dia. <u>6</u> in. to <u>331</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219 MHC</u>		
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20"</u> Set between <u>300</u> ft. and <u>320</u> ft. <u>Perf. 100-300</u> ft. and <u>320-330</u> ft. Gravel pack? <u>yes</u> Size range of material <u>2" Down</u>		
				11. Static water level: <u>67</u> ft. below land surface Date <u>12-11-75</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>97</u> ft. after <u>3</u> hrs. pumping <u>2245</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1245</u> g.p.m.		
				13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds US pump</u> Model number <u>R-2154</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden Grove, Mo.</u> Address <u> </u> Signed <u>[Signature]</u> Date <u>8-3-76</u> Authorized representative				

T
R
E
S
S
E
C
S
W
N
E
S
W
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Triple T. Farms
Kearny County
10-14-75

Location: SW 3-25-35
Circle 3-3 Pivot

0	22	Fine Sand
22	52	Med. to Coarse Gravel (Loose)
52	65	Brown Clay
65	80	Fine to Med. Sand & Gravel (Loose)
80	96	Brown Clay
96	146	Fine to Med. Sand & Gravel (Loose)
146	183	Blue Clay
183	230	Fine to Med. Sand & Gravel (Loose)
230	245	Brown Sandy Clay, Streaks of Gravel, 35%
245	258	Fine to Med. Sand & Gravel (Loose)
258	290	Brown Sandy Clay
290	303	Fine to Med. Sand & Gravel, 10% Clay (Loose)
303	330	Fine to Med. Sand & Gravel (Loose)
330	355	Brown Sandy Clay
355	365	Brown, Gray & Yellow Clay with Brown Rock (Hard)

TD 330'