


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Kearny</b>	Township name <b>Southside</b>	Fraction <b>Piv. SW<sup>1</sup>/<sub>4</sub></b>	Section number <b>6</b>	Town number <b>T 25 S</b>	Range number <b>R 35 W</b>
Distance and direction from nearest town or city: <b>West of Deerfield, Ks. on river road-1 W. 3/4 S, 1/4 E.</b> Street address of well location if in city:				3 Owner of well: <b>Fritz Schreiber Vogel</b> Address: <b>Lakin, Ks. 67860</b>		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		4 Well depth: <u>280</u> ft. Date of completion <u>3-30-75</u> Well diameter <u>26</u> in.
2 Type and color of material				From		To
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Digm. <u>16</u> in. to <u>281</u> ft. depth; Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>   </u> in. to <u>   </u> ft. depth; Weight <u>   </u> lbs./ft.		
				8 Screen: Manufacturer <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot <u>   </u> Length <u>20'</u> Set between <u>200</u> ft. and <u>210</u> ft. <u>260-270</u> Part #s: <u>110-200, 210-260, 270-280</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>   </u> Down		
				9 Static water level: <u>30</u> ft. below land surface Date <u>2-18-75</u>		
				10 Pumping level below land surfaces: <u>50</u> ft. after <u>2</u> hrs. pumping <u>851</u> g.p.m. <u>62</u> ft. after <u>4</u> hrs. pumping <u>315</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>   </u>		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.		
				14 Nearest source of possible contamination: ft. <u>   </u> Direction <u>   </u> Type <u>   </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-FMC</u> Model number <u>03774</u> HP <u>100</u> Volts <u>   </u> Length of drop pipe <u>160</u> ft. capacity <u>800</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation  <b>Well is fairly close to a river.</b>  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley  <b>Good well.</b>				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling 208</b> Business name License No. Address <u>Box 493 Garden City, Ks.</u> Signed <u>M. J. Minter</u> Date <u>3-20-75</u> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

Professional

**MINNIE WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-5249

P.O. Box 493 • GARDEN CITY, KANSAS 67846

Neary County Fritz Schreibvogel February 18, 1975

SW $\frac{1}{4}$  sec. 6 R.25 R.35 Static Water Level 30 Test # 1

Location: West of Deerfield on the river road-1 mile west  
3/4 South, 1/4 East on Pivot Kansas Nebraska  
Booster Station

0	1	Top Soil
1	23	Medium Gravel big Coarse Rock
23	69	Brown Sandy Clay
69	74	Medium Sand & Gravel (Loose)
74	93	Brown Sandy Clay
93	104	Fine to Medium Sand & Gravel, 15% Clay (Tight)
104	112	Brown Sandy Clay
112	140	Fine to Medium Sand & Gravel, Clay Streak
140	154	Brown Sandy Clay
154	210	Medium Sand & Gravel (Loose)
210	215	White Clay (Very Hard)
215	220	Brown Sandy Clay (Hard)
220	253	Brown Sandy Clay
253	280	Fine to Medium Sand & Sand Gravel (Little Tight)
280	320	Yellow Clay
320	330	Shale (Hard Very)

TD 280

20 Ft. Screen