

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620


1 Location of well:	County Kearny	Township name Southside	Fraction NW of SE 1/4	Section number 6	Town number TS 25	Range number RW 32
---------------------	-------------------------	-----------------------------------	---------------------------------	----------------------------	-----------------------------	------------------------------

Distance and direction from nearest town or city: **4 miles south & 3 miles west of Deerfield, Ks.**
Street address of well location if in city:

3 Owner of well: **L.F. Roderick**
Address: **Garden City, Ks. 67840**

Locate with "X" in section below:

Sketch map:



4 Well depth: **320** ft. Date of completion **1-14-75**
Well diameter **26** in.

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

6 Use: Domestic Public supply Industry
 Irrigation Air conditioning Commercial
 Test well

7 Casing: Material **St.** Height: above/below
Threaded Welded Surface **12** in.
Diam. **16** in. to **321** ft. depth Drive shoe? Yes No
Weight **24.2** lbs./ft. **1**

2	Type and color of material	From	To
	Top Soil, Fine Sand	0	5
	Sand & Gravel Coarse (Loose)	5	57
	Sandy Clay	57	74
	Fine to Medium Sand & Gravel (Loose)	74	95
	Clay	95	128
	Very Fine Sand (Loose)	128	145
	Clay	145	208
	Fine to Medium Sand & Gravel (Loose)	208	215
	Sandy Clay 50% Sand to Gravel	215	243
	Fine to Medium Sand & Gravel (Loose)	243	260
	Sandy Clay	260	280
	Very Fine Sand (Loose)	280	290
	Fine to Medium Sand & Gravel (Loose)	290	330
	Fine to Medium Sand & Gravel 30% Clay	330	350
	Yellow	350	365
	(use a second sheet if needed)		

8 Screen: **No screen used.**

Manufacturer _____
Type _____ Dia. _____
Slot/gauze _____ Length _____
Set between _____ ft. and _____ ft.
Permeability: **120-140, 200-260, 290-320**
Gravel pack Yes No Size range of material **1/2" down**

9 Static water level:
45 ft. below land surface Date **1-14-75**

10 Pumping level below land surfaces:
20 ft. after **2** hrs. pumping **827** g.p.m.
62 ft. after **4** hrs. pumping **1254** g.p.m.
Estimated maximum yield **1200** g.p.m.

11 Water sample submitted:
 Yes No Date _____

12 Well head completion:
 Pitless adapter Inches above grade

13 Well grouted? Yes No
 Neat cement Bentonite Clay Puddle
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination: **N/A**
ft. _____ Direction _____ Type _____
Well disinfected upon completion? Yes No

15 Pump: Not installed
Manufacturer's name **FMC-Peerless**
Model number **5020** HP **100** Volts _____
Length of drop pipe **140** ft. capacity **800** g.m.p.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

16 Remarks: elevation **Good well.**
Topography: **No Possible Contamination.**
 Hill
 Slope
 Upland
 Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Minter-Wilson Drig. Co. 200
Business name License No. _____
Address **Box 445 Garden City, Ks.**
Signed **Minter-Wilson** Date **3/13/75**
Authorized representative