


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Kearny	Township name Southside	Fraction SW of NE 1/4	Section number 8	Town number T5 25	Range number RW 35
Distance and direction from nearest town or city: 7 miles South of Deerfield, Ks. Street address of well location if in city:				3 Owner of well: C-C Cattle Co. Address: Ulysses, Ks.		
Locate with "X" in section below: N  S 1 Mile		Sketch map:		4 Well depth: 425 ft. Date of completion 1-27-75 Well diameter 20 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
From				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/2 in. Diam. 10 in. to 420 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 10 in. to 420 ft. depth!		
				8 Screen: Manufacturer Johnson Division Type Galv. Dia. 10" Slot/gauze 100 Length 20' Set between 300 ft. and 400 ft. Perforations: 100-140, 220-300, 400-425 down Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material 20'		
Top soil & fine to med. sand				9 Static water level: 76 ft. below land surface Date 1-25-75		
Fine to coarse sand & gravel (Loose)				10 Pumping level below land surfaces: 104 ft. after 2 hrs. pumping 930 g.p.m. 119 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.		
Fine to med sand & gravel (Loose)				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Clay				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
Clay				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Puddled Depth: From 0 ft. to 10 ft.		
Fine to med. sand & gravel (Loose)				14 Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Clay				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name FMC-Peerless Model number 3119 HP 125 Volts _____ Length of drop pipe 180 ft. capacity 800 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay				16 Remarks: elevation Good Well. Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley No possible contamination.		
Fine to med. sand 30% (Loose)						
Yellow				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name _____ License No. _____ Address Box 493 Garden City, Ks. Signed [Signature] Date 3-13-75 Authorized representative		
Shale						
(use a second sheet if needed)						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5