

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620


1 Location of well:	County Kearny	Township name Southside	Fraction SE of NW¹/₄	Section number 10	Town number TS 25	Range number RW 35
---------------------	-------------------------	-----------------------------------	--	-----------------------------	-----------------------------	------------------------------

Distance and direction from nearest town or city:
7 miles South of Deerfield, Ks.
Street address of well location if in city:

3 Owner of well: **C-C Cattle Co.**
Address: **Ulysses, Ks.**

Locate with "X" in section below:
N

Sketch map:



4 Well depth: 335 ft. Date of completion 1-26-75
Well diameter 26 in.

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

6 Use: Domestic Public supply Industry
 Irrigation Air conditioning Commercial
 Test well

7 Casing: Material St. Height: above/below
Threaded Welded Surface 12 in.
Diam. 16 in. to 336 ft. depth Weight 34.25 lb./ft. 1
Drive shoe? Yes No

2	Type and color of material	From	To
	Top soil & fine to coarse sand & gravel (Loose)	0	45
	Sandy clay	45	63
	Fine to coarse sand & gravel (Loose)	63	215
	Gray rock & clay	215	235
	Fine to med. sand & gravel (Loose)	235	260
	Sandy clay	260	280
	Fine to med. sand & gravel 30% clay	280	310
	Fine to med sand & gravel	310	335
	Broken Rock	335	350
	Blind 1 sack of brown returned	350	
	Broken Rock	350	380
	Yellow	380	387
	Shale	387	395
	(use a second sheet if needed)		

8 Screen:
Manufacturer Johnson Division
Type Galv. Dia. 16"
Slot 100 Length 20'
Set between 250 ft. and 260 ft. 310-320
Perforations: 100-250, 260-310, 320-335
Gravel pack Yes No Size range of material 2 1/2" down

9 Static water level:
62 ft. below land surface Date 1-16-75

10 Pumping level below land surfaces:
73 ft. after 2 hrs. pumping 919 g.p.m.
79 ft. after 4 hrs. pumping 1227 g.p.m.
Estimated maximum yield 1200 g.p.m.

11 Water sample submitted:
 Yes No Date _____

12 Well head completion:
 Pitless adapter 12 Inches above grade

13 Well grouted? Yes No
 Neat cement Bentonite Clay Puddled
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination: N/A
ft. _____ Direction _____ Type _____
Well disinfected upon completion? Yes No

15 Pump: Not installed
Manufacturer's name FMC-Peerless
Model number 3775 HP 125 Volts _____
Length of drop pipe 180 ft. capacity 800 g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

16 Remarks: elevation **Good well.**
No possible contamination.
Topography:
 Hill
 Slope
 Upland
 Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Minter-Wilson Drlg. Co. 208
Business name _____ License No. _____
Address Box 493 Garden City, Ks.
Signed [Signature] Date 3-15-75
Authorized representative