

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>KEARNY</u>	Fraction <u>NE 1/4 SW 1/4</u>	Section number <u>16</u>	Township number <u>25 S R 35</u>	Range number <u>16W</u>
2. Distance and direction from nearest town or city: <u>Across river bridge at Deerfield 1 east 7 south 3/4 west 3/4 north</u>				3. Owner of well: <u>Triple T Farms</u> R.R. or street: <u>(Circle #16-2)</u> City, state, zip code: <u>Lakin, Ks. 67860</u>		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. <u>26</u> in. Completion date <u>10-31-75</u> Well depth <u>400</u> ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height: <u>Above or below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>401</u> ft. depth Wall thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>219MNC</u>		
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>320</u> ft. and <u>340</u> ft. Perf. <u>110-130, 150, 170--190-220</u> Gravel pack? <u>yes</u> Size range of material <u>1/2" Down</u>		
				11. Static water level: <u>62</u> ft. below land surface Date <u>12-9-75</u>		
				12. Pumping level below land surfaces: <u>89</u> ft. after <u>3</u> hrs. pumping <u>1227</u> g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>1200</u> g.p.m.		
				13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>12-9-75</u>		
				14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter <input type="checkbox"/> <u>12</u> inches above grade		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: <u>Not installed</u> Manufacturer's name <u>GuoIdas US Pumps</u> Model number <u>K2159</u> HP <u>100</u> Volts <u>g.p.m.</u> Length of drop pipe <u>160</u> ft. capacity <u>g.p.m.</u> Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden City, Ks</u> Address <u>8-3-76</u> Signed <u>[Signature]</u> Date <u>8-3-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Triple T. Farms
Kearny County
10-3-75

Location: NE 16-25-35
Going South of Tate Lane from Deerfield, 2½ miles
South, ¼ West, 20 feet West of Pivot

Test # 1

0	16	Top Soil, Fine Sand
16	88	Med. Coarse Gravel (Loose)
88	97	Brown Sandy Clay
97	112	Med. Sand & Gravel, 10% Clay (Tight)
112	134	Fine to Med. Sand & Gravel (loose)
134	147	Brown Sandy Clay
147	155	Med. Sand & Gravel (Loose)
155	171	Fine to Med. Sand & Gravel
171	194	Brown Sandy Clay
194	221	Fine to Med. Sand & Gravel, Clay Streaks
221	226	Brown Sandy Clay
226	230	Fine to Med. Sand & Gravel, Clay Streaks
230	255	Fine to Med. Sand & Gravel
255	262	Brown Sandy Clay
262	276	Fine to Med. Sand & Gravel
276	293	Brown, White Clay mixed with White Rock
293	320	Fine to Med. Sand (Tight)
320	335	Fine to Med. Sand & Gravel (Loose)
335	366	Med. Sand & Gravel (Loose)
366	375	Fine to Med. Sand (Loose)
375	397	Fine to Med. Sand
397	415	Fine to Med. Sand (Tight)
415	425	Fine to Med. Sand mixed Brown Rock, Streaks of Clay
425	440	Yellow Clay (Hard)
440	445	Shale

TD 400'