

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County KEARNY	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 18	Township number T 25 S	Range number R 3 W
2. Distance and direction from nearest town or city: 2 1/2 miles south, 2 1/2 miles east of north of Lakin, Ks. Street address of well location if in city:			3. Owner of well: Hinter-Wilson Drilling Co. R.R. or street: Box A City, state, zip code: Garden City, Ks. 67846		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date: 1-26-86 Well depth 385 ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material steel Height: Above ground 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 386 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219MPC	
5. Type and color of material			From	To	10. Screen: Manufacturer's name: Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 350 ft. and 370 ft. Perf. 130-175 ft. and 200-260, 320-380, 370-385 Gravel pack? yes Size range of material: 12-31-75
					11. Static water level: <input type="checkbox"/> mo./day/yr. 64 ft. below land surface Date 12-31-75
					12. Pumping level below land surfaces: 100 ft. after 3 hrs. pumping 1297 g.p.m. 100 ft. after 7 hrs. pumping 1297 g.p.m. Estimated maximum yield 1297 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: N/A ft. _____ Direction _____ Type <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: Goulds US Pumps Manufacturer's name GIC HP 100 Volts _____ Model number 12 GIC Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hinter Wilson Drilling 208 Business name Box A Garden City, Ks. Address _____ Signed [Signature] Date 8-3-76 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Minter-Wilson

CHUCK JAEGER
Kearny County
11-28-75

Location: SW 18-25-35
30 feet East of Pivot
Pivot 32

Static Water Level: 80'

0	2	Top Soil
2	12	Fine Sand
12	37	Med. Coarse Gravel (Loose)
37	46	Brown Sandy Clay
46	62	Med. Sand & Gravel
62	91	Brown Sandy Clay
91	111	Med. Sand & Gravel
111	128	Brown Sandy Clay, Gravel Streaks
128	143	Fine to Med. Sand, & Gravel, Clay Streaks
143	174	Med. Sand & Gravel
174	181	Brown Sandy Clay
181	202	Blue Clay
202	213	Fine to Med. Sand & Gravel (Loose)
213	225	Brown Sandy Clay
225	238	Fine to Med. Sand & Gravel, 20% Clay
238	252	Brown Sandy Clay
252	259	Fine to Med. Sand
259	283	Brown Sandy Clay
283	300	Brown Sandy Clay, Gravel Streaks
300	326	Brown Sandy Clay
326	369	Fine to Med. Sand (Tight)
369	384	Fine to Med. Sand
384	400	Yellow Clay
400	415	Shale

T.D. 385'