

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>KEARNY</b>	Fraction <b>SE NW</b> <del>SW</del> SE 1/4 NW 1/4	Section number <b>20</b>	Township number T <b>25</b> S	Range number R <b>35</b> W
2. Distance and direction from nearest town or city: <b>2 1/4 east 3 south 1 1/4 east 1/4 south</b>			3. Owner of well: <b>Wayne Thornbrough</b> R.R. or street: <b>45 Laurel St.</b> City, state, zip code: <b>Concord, Mass. 01742</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>4-30-76</u> Well depth <u>316</u> ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>317</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
5. Type and color of material			From	To	10. Screen: Manufacturer's name <b>Johnson Division</b> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>240</u> ft. and <u>260</u> ft. Perf. <u>120-240</u> ft. and <u>260-316</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>4-22-76</u>
					11. Static water level: <input type="checkbox"/> mo./day/yr. <u>63</u> ft. below land surface Date <u>4-22-76</u>
					12. Pumping level below land surfaces: <u>110</u> ft. after <u>3</u> hrs. pumping <u>1300</u> p.m. <u>    </u> ft. after <u>1300</u> hrs. pumping <u>    </u> g.p.m. Estimated maximum yield <u>    </u> g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <u>    </u>
					14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: <u>N/A</u> ft. <u>    </u> Direction <u>    </u> Type <u>    </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>FMC - Peerless Pump</u> Model number <u>121B</u> HP <u>100</u> Volts <u>    </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden City, Kas</u> Address <u>    </u> Signed <u>    </u> Date <u>8-12-76</u> Authorized representative
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

25  
 35  
 20 SE NW NW  
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3

The  
Professionals

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

**THORNBROUGH**

(CABELL - TENNANT)

2-26-76

LOCATION: NW 20-25-35  
30 Feet West Of pivot

STATIC WATER LEVEL 60'

TEST NO. 104

D	12	Fine Sand
12	48	Fine To Med. Sand & Gravel (Some Coarse Gravel) Streaks Of Clay (10%)
48	66	Brown Sandy Clay
66	110	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
110	124	Fine To Med. Sand & Gravel, Streaks Of Clay 20% (Tight)
124	132	Brown Sandy Clay
132	162	Fine To Med. Sand & Gravel, Streaks Of Clay (10%) (Loose)
162	170	Fine To Med. Sand, Streaks Of Clay (10%)
170	184	Fine Sand, Blue Clay, Brown Clay Mixture (No Good)
184	188	White Rock (Hard)
188	202	Fine To Med. Sand & Gravel (Loose)
202	233	Fine To Med. Sand & Gravel, Streaks Of Clay (10%) (Loose)
233	260	Fine To Med. Sand & Gravel (Loose)
260	298	Brown Sandy Clay
298	316	Fine To Med. Sand & Fine Gravel, Streaks Of Clay (10%)
316	350	Brown Sandy Clay
350	380	Fine Sand & Clay Mixture (10%) No Good
380	387	Brown & Yellow Clay (Tight)
387	390	Shale