

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

F-11

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County KEARNY	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 20	Township number T 25 S R 35	Range number 35
2. Distance and direction from nearest town or city: from Lakin 1 south 2 1/2 east 4 south 1 3/4 east 1/4 north			Owner of well: Wayne Thornbrough		
Street address of well location if in city:			R.R. or street: 45 Laurel St.		
			City, state, zip code: Concord, Mass. 01742		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 4-30-76 Well depth 370 ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From		9. Casing: Material steel Height: Above or Below	
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 371 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MNC	
				10. Screen: Manufacturer's name Johnson Division	
				Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 210 ft. and 260 ft. Perf. 120-240 ft. and 260-370 ft. Gravel pack <input checked="" type="checkbox"/> Size range of material 4-22-76 3/8" Down	
				11. Static water level: 63 ft. below land surface Date 4-22-76 mo./day/yr.	
				12. Pumping level below land surfaces: 93 ft. after 3 hrs. pumping 1350 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1350 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name FMC Peerless Model number 121B HP 100 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter Wilson Drilling 208 Business name O. Box A garden City, Mo. Address Signed [Signature] Date 4-12-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

THORNBOUGH
NEARBY COUNTY
3-1-76

LOCATION: SE 20-25-35
30 Feet East Of Pivot

STATIC WATER LEVEL: 80'

TEST F-11

0	1	Top Soil
1	12	Fine Sand
12	16	Brown Clay
13	65	Fine To Med. Sand & Gravel, Streaks Of Coarse Gravel (Loose)
65	95	Brown Sandy Clay
95	170	Fine To Med. Sand & Gravel (Loose)
170	189	Fine To Med. Sand & Fine Gravel (Little Tight)
189	200	Blue Clay, Streak Of Fine To Med. Sand (20%) (Tight)
200	217	Fine To Med. Sand, Streaks Of Clay (10%) (Loose)
217	260	Fine To Med. Sand & Fine Gravel (Loose)
260	274	Fine To Med. Sand, Streak Of Clay (15%) Little Tight
274	310	Fine To Med. Sand & Gravel, Streaks Of Clay (10%) (Loose)
310	352	Fine Sand & Clay Mixture (No Good) (Tight)
352	370	Fine To Med. Sand, Streaks Of Clay (10%) (Loose)
370	383	Brown Sandy Clay, Small Streaks Of Fine Sand
383	390	Brown, Yellow Clay (Tight)