


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

C-5

1. Location of well:	County <b>KEARNY</b>	Fraction <b>SE 1/4 NE 1/4 SW 1/4</b>	Section number <b>20</b>	Township number <b>T 25 S</b>	Range number <b>R 35 E/W</b>
2. Distance and direction from nearest town or city: <b>From Lakin 1 south 2 1/2 east 1/2 south 1 1/2 east 1/2 north</b> Street address of well location if in city:			3. Owner of well: <b>Wayne Thornbrough</b> R.R. or street: <b>45 Laurel St.</b> City, state, zip code: <b>Concord, Mass 01742</b>		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. <b>26</b> in. Completion date <b>4-30-76</b> Well depth <b>378</b> ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>379</u> ft. depth Wall Thickness: inches or Dia. <u>  </u> in. to <u>  </u> ft. depth gage No. <u>  </u>
					10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>340</u> ft. and <u>360</u> ft. Perf. <u>120 240</u> ft. and <u>360 378</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>3/8" Dwon</u>
					11. Static water level: <u>57</u> ft. below land surface Date <u>4-22-76</u> mo./day/yr.
					12. Pumping level below land surfaces: <u>78</u> ft. after <u>3</u> hrs. pumping <u>1325</u> g.p.m. <u>  </u> ft. after <u>  </u> hrs. pumping <u>  </u> g.p.m. Estimated maximum yield <u>1325</u> g.p.m.
					13. Water sample submitted: <u>  </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>  </u>
					14. Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <u>  </u> inches above grade
					15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: <u>N/A</u> ft. <u>  </u> Direction <u>  </u> Type <u>  </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-PMC</u> Model number <u>121B</u> HP <u>100</u> Volts <u>  </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wisconsin Drilling 208</u> Business name <u>  </u> Box <u>A</u> Garden City, Mo. Address <u>  </u> Signed <u>  </u> Date <u>5-12-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 25 S 35 E R 35 E Sec 20 NE SW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

THORNBROUGH  
KEARNY COUNTY  
(CAMPBELL)  
3-2-76

LOCATION: **SU** 20-25-35  
30 Feet East Of Pivot

STATIC WATER LEVEL: 80'

TEST #C-5

0	1	Top Soil
1	10	Fine Sand
10	12	Brown Clay
12	47	Med. To Coarse Gravel
47	52	Brown Sandy Clay
52	167	Fine To Med. Sand & Gravel (Loose)
167	185	Fine To Med. Sand & Gravel, Streaks Of Clay (10%) (Loose)
185	250	Fine To Med. Sand & Gravel (Loose)
250	260	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
260	277	Brown Sandy Clay, Streak Of Fine To Med. Sand & Gravel (25%)
277	310	Brown Sandy Clay
310	330	Fine Sandy & Clay Mixture (No Good)
330	340	Fine To Med. Sand & Fine Gravel, Streak Of Clay (10%)
340	378	Fine To Med. Sand & Gravel (Loose)
378	385	Brown Clay (Tight)
385	390	Yellow Clay (Hard - Used Pull Down)