

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

F-10

1. Location of well:		County KEARNY	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 20	Township number T 25	Range number S R 35	R/W
2. Distance and direction from nearest town or city: 2 1/4 east 3 south 1 3/4 east 1/4 south Street address of well location if in city:			3. Owner of well: Wayne Thornbrough R.R. or street: 45 Laurel St. City, state, zip code: Concord, Mass. 01742				
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: 		6. Bore hole dia. 26 in. Completion date 4-30-76 Well depth 370 ft.	
5. Type and color of material				From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
						9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 371 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <input type="checkbox"/>	
						10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 330 ft. and 350 ft. Perf. 120-330 ft. and 350-370 ft. Gravel pack? yes Size range of material 1/2" D50	
						11. Static water level: <input type="checkbox"/> mo./day/yr. 61 ft. below land surface Date 4-22-76	
						12. Pumping level below land surfaces: 98 ft. after 3 hrs. pumping 250 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1250 g.p.m.	
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
						15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 .	
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name EmC Peerless Pump Model number 121B HP 100 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter Wilson Drilling 208 Business name Box A Garden City, Mo. Address Box A Garden City, Mo. Signed W. Wilson Date 8-12-76 Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

25 35 20 NE SW NE 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

THORNBOUGH
(FLETCHER)
3-1-75

LOCATION: NE 20-25-35
30 Feet East Of Pivot

STATIC WATER LEVEL: 80'

TEST #F10

0	3	Top Soil
3	12	Brown Sandy Clay
12	82	Fine To Med. Sand & Gravel (Loose)
82	100	Brown Sandy Clay
100	142	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
142	154	Fine To Med. Sand & Gravel, Streaks Of Clay (20%)
154	175	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
175	181	Brown Sandy Clay
181	230	Fine To Med. Sand & Gravel (Loose)
230	277	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
277	316	Brown Sandy Clay
316	350	Fine To Med. Sand & Gravel (Loose)
350	370	Fine To Med. Sand & Fine Gravel, Streaks Of Clay (10%)
370	395	Fine To Med. Sand, Streaks Of Clay (15%) Tight
395	400	Brown, Yellow Clay (Hard, Used Pull Down)