

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

#21-1

1. Location of well:	County Kearny	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 21	Township number T 25 S	Range number R 35
2. Distance and direction from nearest town or city 6 west of Deerfield on river rd. 3/4 south 3/4 west Street address of well location if in city:			3. Owner of well: Brad Tate R.R. or street: Lakin, KS 67860 City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 12-20-76 Well depth 351 ft.
					7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other
					9. Casing: Material steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC ___ Weight 36.87 lbs./ft. Dia. 16 in. to 352 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gauge No. ___
					10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16 in. Slot/gauze ___ Length 20 ft. Set between 320 ft. and 340 ft. Perf. 120-320 ft. and 340-251 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/2 in. down
					11. Static water level: ___ mo./day/yr. 82 ft. below land surface Date 12-4-76
					12. Pumping level below land surfaces: 124 ft. after 2 hrs. pumping 700 g.p.m. 147 ft. after 4 hrs. pumping 1050 g.p.m. Estimated maximum yield ___ g.p.m.
					13. Water sample submitted: ___ mo./day/yr. Yes <input checked="" type="checkbox"/> No Date ___
					14. Well head completion: ___ Pitless adapter ___ 12 Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> yes With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: N/A ft. ___ Direction ___ Type Field mnc Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No
					17. Pump: Not installed Manufacturer's name Goulds U.S. Pumps Model number 76564 HP 125 Volts ___ Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other
			(Use a second sheet if needed)		
18. Elevation: Topography: ___ Hill <input checked="" type="checkbox"/> Slope ___ Upland ___ Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. 67846 Address Box A Garden City, KS 67846 Date 2-24-77 Authorized representative		

25 35 21 SW 1/4 SE NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TATE
KEARNY COUNTY
11-22-76

Location: NW 21-25-35 3 mile south of Tate headquarters 3/4
west 1/4 north 300 Ft. south of pivot
Static Water Level- 80'

Test # 21-1-A

0	19	Fine sand
19	78	Fine to med. sand and gravel
78	121	Brown clay
121	144	Fine to med. sand and gravel
144	183	Blue clay
183	191	Fine to med. sand and gravel
191	210	Brown clay
210	216	Fine to med. sand and gravel
216	229	Fine to med. sand and gravel 20% clay
229	246	Fine to med. sand and gravel
246	291	Brown clay
291	310	Fine to med. sand and gravel
310	321	Brown clay
321	251	Fine to med. sand and gravel
351	366	Fine sand
366	410	Brown clay

T.D. 351